



THE ASSAM
ROYAL GLOBAL UNIVERSITY
GUWAHATI

CRITERION 4

INFRASTRUCTURE AND LEARNING RESOURCES

KEY INDICATOR
4.4.2

**Maintenance of
Campus Infrastructure**

AC LOG BOOK

Date	Sl. no	Location	Complain	Com-time	Att-time	Remarks	Indentification	Sing.
01/03/24	11	A-Block	4th floor All Blue servicing.	"	"	Done	Servicing.	
02/03/24	"	A-Block	3rd floor 4 nos Blue filter and Stanner cleaning.	"	"	Done	Servicing.	
	"	A-Block	2nd floor 4 nos Blue filter and Stanner cleaning.	"	"	Done	Servicing.	
03/03/24	"	A-Block	1st and 2nd floor 2 nos Blue filter and Stanner cleaning.	"	"	Done	Servicing.	
04/03/24	"	A-Block	1st floor 3 nos Blue filter and Stanner cleaning.	"	"	Done	Servicing.	Am
	"	A-Block	Seminar hall cassette AC filter cleaning.	"	"	Done	Servicing.	
05/03/24	"	A-Block	Seminar hall cassette AC All Stanner cleaning.	"	"	Done	Servicing.	
	"	A-Block	1st floor 2 nos Blue filter and Stanner cleaning.	"	"	Done	Servicing.	
06/03/24	"	Harsha house	Harsha house 2A Blue screw motor fitting.	"	"	Done	Servicing.	
		Harsha house	Harsha house 4th floor lift front door Blue screw motor fitting.	"	"	Done	Servicing.	JIMMY

Date	Sl. no	Location	Complain	Com-time	Att-time	Remarks	Identification	Sign.
07/03/24	1	A-block	Chiller Cassette de filter cleaning.			done	servicing	
08/03/24		A-block	mp Hall shoe unit filter and strainer cleaning. (9 nos)			done	servicing	
09/03/24		A-block	mp Hall shoe filter and strainer cleaning. (9 nos)			done	servicing.	
10/03/24		Aditya house	2nd floor Freezer unit fitting and canvas new fitting.			done	servicing.	
11/03/24		Plant Room	Plant Room Secondary Pump Bearing fitting.			done	servicing.	Jim
12/03/24		Plant Room	Plant Room Pipe line Insulation.			done	servicing.	
13/03/24		Plant Room	Cooling Tower Base cleaning.			done	servicing	
14/3/24		plant room	motor servicing					
15/3/24		"	"				servicing	
16/3/24		"	"				servicing.	
18/3/24		Harsha house	pressure test. Valve				servicing	
19/3/24		"	"				"	
20/3/24		"	"				"	

Date	SLNO	Location	complain	Comp Time	ATT Time	remark	Identification
21/3/24	1	Harsha House	preventive maintenance			Done	servicing
	2	Management	water leakage.	12:00 PM	1:30 PM	Done	servicing.
22/3/24	1	Harsha House	preventive maintenance			Done	servicing
	2	E 102	AC not working	2:00 PM	2:25 PM	Done	drum block
	3	Admin	" " "	2:10 PM	2:40 PM	Done	sensor fault
23/3/24	1	Harsha House	preventive maintenance			Done	servicing
25/3/24		" "	" "			Done	"
26/3/24		" "	" "			Done	"
27/3/24		" "	" "			Done	"
28/3/24		" "	" "			Done	"
29/3/24		" "	" "			Done	"
30/3/24		" "	" "			Done	"
1/4/24	1	Aditya house	" "			Done	"
	2	Aditya warden office	AC not working	11:30 AM	12:10 PM	Done	filter clean.
2/4/24		Aditya house	preventive maintenance			Done	servicing.
3/4/24		B Top chikan	Cooling Tower servicing			Done	"
3/4/24		"	Desludging			Done	"
4/4/24		"	motor servicing			Done	"
5/4/24	1	"	" "			Done	"
	2	Server	AC not cooling			Done	"
	3	Reception	" " "			Done	Repair.

[Handwritten signature]

Date	SL NO	Location	complexin	com Time	ATT Time	Revenue Due	Identification Servicing	Stom.
6/4/24	6/4/24	Ashya house	preventive maintenance					
8/4/24		u u	u u			u	u	
9/4/24		u u	u u			u	u	
10/4/24		u u	u u			u	u	
11/4/24		u u	u u			u	u	
12/4/24		u u	u u			u	u	
13/4/24		u u	u u			u	u	
15/4/24		block DEF	u u			u	u	
16/4/24		u u	u u			u	u	
17/4/24		u u	u u			u	u	
18/4/24		u u	u u			u	u	
19/4/24		u u	u u			u	u	
20/4/24		u u	u u			u	u	
22/4/24	1	B 301	AC Not cooling	9:10 AM	10:40 AM	u	Repair	
	2	A. 305	u u u	10:50 AM	12:30 PM	u	u	
	3	A. 110	u u u	2:10 PM	2:40 PM	u	u	
	4	A. 210	AC noise	2:10 PM	3:10 PM	u	Motor Repair.	
28/4	1	B. 101	AC Not working	10:40 AM	11:00 AM	u	Repair.	
	2	C. 204	u u u	10:40 AM	11:30 AM	u	u	
	3	D. 205	u u u	2:40 PM	3:10 PM	u	u	

[Handwritten signature]

Date	SLNO	Location	Complains
24/4/24	1 2	2 A H House	AC not cooling
	3	B C n n	n n n
	4	A. 404	n n n
	5	B. 502	n n n
		C - 303	n n n
25/4	1	B 11C	AC NOT cooling
	2	Guest house	n n n
	3	vc office	n n n
26/4	1	Aditya 2C	AC not cooling
	2	Aditya unwinidng	1 n n
27/4	1	H. house 5B	AC not cooling
	2	n n 2D	n n n
	3	A House 6A	n n n
	4	L. 5D	n n n
29/4/24	1	C 102	AC Not working
	2	C 501	n n n
	3	C 502	n n n
	4	H. house 3D	n n n
	5	n n 2C	n n n
30/4/24	1	F 504	AC Not cooling
	2	F 503	n n n
	3	F 502	n n n
	4	KAC	n n n
1/5/24	1	A. 204	AC Not cooling
	2	B 504	n n n
	4	1 204	n n n
	5	Admin	n n n
	6	Account	n n n

Com Time	ATT Time	Result	Identification	Stat.
11:10 AM	3:30 PM	Done	Repair	
11:10 AM	3:30 PM	n	n	
11:20 AM	12:40 PM	n	n	
2:00 PM	3:10 PM	n	n	
2:40 PM	3:00 PM	n	n	
9:40 AM	10:10 AM	n	n	
9:40 AM	12:10 PM	n	n	
10:30 AM	10:50 AM	n	Setting.	
9:10 AM	4:20 PM	n	Repair.	
9:10 AM	4:20 PM	n	sensor problem.	
10:40 AM	12:10 PM	n	searching.	
10:40 AM	12:10 PM	n	Stemmer clean.	
11:00 AM	11:50 AM	n	filter clean.	
2:00 PM	3:40 PM	n	n n	
9:10 AM	9:40 AM	n	Setting.	
9:40 AM	11:20 AM	n	power problem.	
9:40 AM	11:20 AM	n	n n	
11:50 AM	12:10 AM	n	Repair.	
11:50 AM	12:40 PM	n	n	
10:40 AM	2:00 PM	n	Repair.	
10:40 AM	2:00 PM	n	n	
10:40 AM	2:00 PM	n	n	
12:50 PM	1:20 PM	n	n	
10:20 AM	10:40 AM	n	power problem.	
11:10 AM	1:40 AM	n	Repair	
11:40 AM	2:30 PM	n	n	
11:40 AM	11:55 AM	n	n	
12:55 PM	5:00 PM	n	Gas leakage	

[Handwritten signature]

Date	SL No	Location	Complain	Com Time	ATT Time	Remark	Identification	Sign.
2/5/24	1	A. 304	Ac Not cooling	9:30 AM	2:20 PM	Done	Report	
	2	A. 405	n n n	9:30 AM	10:50 AM	n	n	
	3	C. 307	n n n	9:40 AM	2:00 PM	n	n	
	4	A. House 2 E	n n n	11:50 AM	12:10 PM	n	n	
	5	B. 301	overc cooling	3:10 PM	4:50 PM	n	n	
	6	B. 405	Ac Not cooling	4:00 PM	4:10 PM	n	Setting	
	7	A. 203	Ac Not cooling	4:10 PM	5:00 PM	n	Stemmen clean.	
3/5/24	1	Server room	Ac Not working	9:00 AM	9:40 AM	Done	filter clean	
	2	Management	n n n	9:10 AM	9:20 AM	Done	n n	
	3	Admin	n water leakage.	12:10 PM	1:00 PM	Done	drain block	
	4	A. 210	Ac not cooling.	1:20 PM	4:10 PM	Done	Stemmen clean	
	5	B 202	n n n	1:20 PM	5:10 PM	Done	n n	
4/5/24	1	Ashya 4B	Ac Not cooling	9:40 AM	3:00 PM	Done	Report	
	2	n 3C	n n n	9:40 AM	3:00 PM	Done	n	
	3	n 6B	n n n	9:40 AM	3:00 PM	Done	n	
	4	Hymee house 3C	Ac Not cooling	10:40 AM	11:40 AM	n	n	
	5	H house 2A	n n n	10:40 AM	5:00 PM	n	n	
	6	n n 3B	n n n	10:40 AM	5:00 PM	n	n	
	7	n n 1A	n n n	10:40 AM	5:00 PM	n	n	
	8	n n 1C	n n n	10:40 AM	5:00 PM	n	n	
6/5/24	1	A 410	Ac Not cooling	9:20 AM	10:10 AM		filter clean	
	2	Cafeteria	water leakage.	10:10 AM	11:20 AM		Drain block	
	3	A 206	Noise	10:00 AM	2:00 PM		Bevery change	
	4	B 412	n	11:40 AM	12:55 PM		Seavring	
	5	B 407	Cooling less	12:10 PM	12:40 PM		filter clean	
	6	B 307	Not cooling	12:10 PM	2:50 PM		n	
	7	Reception	Not n	2:10	2:30	n	f. filter clean	
	8	Air gallery	n n	2:10	2:40	n	Setting	
	9	C 605	n n	3:00	3:20	n	Setting	
	10	C 603	n n	3:00	3:20	n	n	
	11	A House 6B	Leavage	3:00 PM	5:00	Done	Drain block	

[Signature]

Date	SL NO	Location	Complain
7/5/24	1	B 102	Ac Not working
	2	C 203	" " "
8/3/24	1	Aditya 2B	Ac Not working
	2	" 3D	" " "
	3	C 307	" " "
	4	F 102	" " "
9/9/24	1	A 405	AC not cooling
	2	B 506	" " "
	3	Hirsha 3C	" " "
11/5/24	1	Reception	Ac Not cooling
	2	B 101	" " "
	3	Server	" " "
	4	I 201	" " "
13/5/24	1	F 205	Ac water leakage
	2	F 204	" " "
	3	Aditya 6B	Ac Not working
14/5/24	1	A. 203	Ac Not working
	2	C. 506	" " "
	3	C. 505	" " "
	4	Samayya 303	" " "
15/5/24	1	Auditorium	cooling less
	2	BB 412 412	No cooling
	3	BB 507	" "
	4	B 405	" "
	5	B 512	" "
	6	A-301	" "
	7	C. 401	" "

Com Time	ATT Time	Identification	status	Day
10:40 AM	11:10 AM	Report	Due	
1:57 PM	2:40 PM	"	"	
10:10 AM	11:20 AM	filter clean	Due	
10:10 AM	11:50 AM	status check	"	
12:00 PM	1:10 PM	Repair	"	
2:30 PM	3:00 PM	setting problem	"	
9:30 AM	11:00 AM	Repair	Due	A
10:20 AM	10:50 AM	"	"	
2:40 PM	3:50 PM	"	"	
9:00 AM	9:20 AM	setting	Due	
9:20 AM	9:40 AM	power fault	"	
9:50 AM	10:10 AM	Repair	"	
2:20 PM	3:10 PM	"	"	
9:50 AM	11:00 AM	Repair	Due	
"	"	"	"	
12:50 PM	1:50 PM	"	"	
9:30 AM	10:20 AM	power fault	Due	
10:10 AM	10:30 AM	setting	"	
"	"	"	"	
2:30 PM	5:00 PM	Repair	"	
10:00 AM	10:30 AM	No power	Due	
11:00 AM	12:40 PM	filter clean	"	
11:20 AM	12:40 PM	" "	"	
2:40 PM	4:00 PM	Reset	"	
2:40 PM	4:00 PM	"	"	
2:40 PM	5:00 PM	filter clean	"	
3:10 PM	4:30 PM	Repair	"	

~~Handwritten mark~~

Date	SL NO	Location	Complains	Com Time	ATT Time	Status	Identification	Signer
16/5/24	1	A 505 405	AC Not working	11:40 AM	11:55 AM	Done	web trip	
	2	C 206	n n n	2:40 PM	3:10 PM	n	Repair	
17/5/24	1	Guest house G2	⊕ AC Not working	10:10 AM	10:50 AM	Done	Repair	
	2	D Seminar hall	n n n	11:20 AM	10:30 AM	Done	Reset	
	3	A 401	water leakage	2:40 PM	3:10 PM	n		
	4	A-307	AC not working	2:40 PM	4:00 PM	Done	Repair	
	5	L-202	n n n	3:10 PM	5:00 PM	n	n	
18/5/24	1	Aditya-3D	AC not working	10:30 am	11:10 am	Done	Repairing	
	2	" 5E4	AC not working	11:30 am	12:00 pm	Done	"	
	3	" 2E2	AC is not working	12:10 pm	1:30 pm	Done	"	
	4	" 1E	AC not working	12:30 pm	5:10 pm	Done	"	
19/5/24	1	A-3A	AC not working	10:10 am	10:40 am	Done	motor damage	
	2	A-6E3	AC not working	11:10 am	12:40 pm	Done	Repairing	
	3	6E2	water leakage	2:00 pm	3:30 pm	Done	Filter Block	
	4	3B1	AC not working	3:40 pm	4:10 pm	Done	Stammer Block	
	5	5E2	AC not working	4:20 pm	5:20 pm	Done	Filter and Stammer Block	
20/5/24	1	Aditya h-6E5	AC not working	9:40 am	10:30 am	Done	Repairing	
	2	" 4D3	AC not working	10:40 am	12:10 am	Done	Repairing	
	3	" 5B11	AC not cooling	12:10 am	2:10 am	Done	motor damage	
	4	" 6E1	AC not cooling	2:10 am	4:20 am	Done	Filter and Stammer Block	
21/5/24	1	Aditya h-4E6	AC not working	10:10 am	10:50 am	Done	Filter and Stammer cleaning	
	2	" 6A1	AC not cooling	11:20 am	12:30 pm	Done	Stammer Block	
	3	" 6B11	AC not working	1:10 pm	2:20 pm	Done	Filter and Stammer Block	
	4	" 4E6	AC not working	3:40 pm	4:50 pm	Done	motor damage	
22/5/24	1	5E Aditya	AC not working	9:40 am	10:50 am	Done	Repairing	
	2	5D "	AC not working	11:00 am	12:20 pm	Done	Filter and Stammer Block	
	3	3E "	AC not cooling	12:40 pm	1:40 pm	Done	Stammer Block	
	4	2A "	AC not cooling	2:50 pm	4:20 pm	Done	web change	

Date	Sr no	Location	Complain	Com fine	Att fine	Status	Identification	Signy
25/05/22	1	Aditya 6UK	Ac not working.	10.10 am	11.10 am	Done	Reset	
	2	" 4UR	Ac not working.	11.20 am	11.40 pm	Done	Reset	
	3	" 1EG	Ac not cooling.	11.50 am	1.00 pm	Done	Filter and stopper labels	
	4	" 2EE	Ac not cooling.	2.20 pm	4.30 pm	Done	Stopper blocks.	
26/05/22	1	Aditya house 3B	Ac not working.	10.10 am	10.40 am	Done	Filter blocks.	
	2	" 9A1	Ac not working.	10.50 am	11.40 am	Done	Stoppers and filter block.	
	3	" 5E2	Ac not working.	12.10 pm	1.40 pm	Done	Filter and stopper block.	
	4	" 4A	Ac not working.	2.30 pm	4.10 pm	Done	motor Damage	
22/05/22	1	Horsha house 3B	Ac not working.	9.50 am	10.30 pm	Done	motor Damage.	
	2	" 6EW	Ac not working.	11.40 am	12.30 pm	Done	Filter and stopper labels	
	3	" 5E1	Ac not working.	12.40 pm	1.50 pm	Done	Stopper blocks.	
	4	" 5CW	Ac not working.	2.30 pm	4.10 pm	Done	motor capacitor short.	
28/05/22	1	Horsha 1B II	Ac not working.	10.10 am	10.50 am	Done	Stopper labels.	
	2	" 1E II	Ac not cooling.	11.10 am	12.20 pm	Done	Filter blocks.	
	3	" 3D	Ac not cooling.	12.30 pm	1.50 pm	Done	motor Damage.	
	4	" 4E II	Ac not cooling.	2.40 pm	4.25 pm	Done	Filter and stopper labels.	
29/05/22	1	Horsha house 6DH	Ac not working.	9.30 am	10.40 am	Done	Room ducts repairing	
	2	" 4B II	Ac not working.	11.10 am	12.30 pm	Done	Room ducts repairing	
	3	" 2E5	Ac not working.	1.30 pm	2.50 pm	Done	Filter and stopper labels.	
	4	" 1B II	Ac not working.	3.10 pm	4.30 pm	Done	motor Damage.	
	5	" 3C	Ac not working.	4.40 pm	5.40 pm	Done	Filter and stopper labels	
30/05/22	1	Service	Horsha house 6A and 6B PPM	10.20 am	11.10 am	Done	Service.	
	2	Service	Horsha house 6C and 6D PPM	11.20 am	12.30 pm	Done	Service.	
	3	Service	Horsha house 5B and 5A PPM	12.40 pm	2.30 pm	Done	Service.	
	4	Service	Horsha house 5C and 5D PPM	3.10 pm	4.20 pm	Done	Service.	
	5	Service	Horsha house 4A and 4B PPM	4.40 pm	5.20 pm	Done	Service.	
31/05/22	1	Horsha house	4C and 4D A/c PPM	10.20 am	11.40 am	Done	A/c unit servicing.	
	2	Horsha house	2A and 3D A/c PPM	11.50 am	12.50 pm	Done	A/c unit servicing.	
	3	Horsha house	2E and 3D A/c PPM.	1.10 pm	2.50 pm	Done	unit servicing.	

DDMMYY

DDMMYY

Date	Sl no	Location	Complain	From time	Att time	Status	Indep. Identification	Solve.
1/6/24	1	Norsha 3 B W	Ac not working.	10.10 am	11.30 am	Done	Filter and Stammer block.	
	2	Norsha 5 E W	Ac not working.	11.40 am	12.10 pm	Done	motor Damage.	
	3	Norsha 8 B W	Ac not working.	12.30 pm	1.40 pm	Done	Stammer Block.	
	4	Norsha 5 B 1	Ac not cooling.	2.10 pm	3.40 pm	Done	Filter and Stammer block.	
	5	Norsha 4 B W	Ac not cooling.	3.50 pm	4.20 pm	Done	Filter Block.	
2/6/24	1	Norsha 2 E 5	Ac not working.	10.10 am	11.20 am	Done	Stammer block.	
	2	Norsha 1 E W	Ac not working.	11.30 am	12.40 pm	Done	Filter and Stammer block.	
	3	Norsha 3 A W	Ac not cooling.	1.40 pm	2.50 pm	Done	Stammer Block.	
	4	Norsha 6 E W	Ac not working.	3.10 pm	4.50 pm	Done	Drill close.	
03/6/24	1	B-202	Ac not working.	10.10 am	10.50 am	Done	Switch Damage.	
	2	BB-412	Ac not working.	11.30 am	12.40 pm	Done	Capacitor Damage.	
	3	B-192	Ac not working.	12.50 pm	1.40 pm	Done	Loose connection.	
	4	Plant Room	Cooling tower level cleaning.	2.30 pm	3.20 pm	Done	Reset Block.	
	5	Norsha house	4A Blue unit Filter, Stammer and Capacitor change.	3.30 pm	4.40 pm	Done	Filter and Stammer block.	
04/06/24	1	Norsha house	2a and 2b Blue unit Filter.	10.10 am	11.30 am	Done	Filter and Stammer cleaning.	Amin
	2	Norsha house	2e and 2d Blue unit Filter.	11.40 am	12.50 pm	Done	Stammer and Filter Block.	
	3	Norsha 2 E W	Ac not working.	1.30 pm	2.20 pm	Done	Stammer block.	
	4	Aditya 2 E W	Ac not working.	2.40 pm	4.10 pm	Done	motor Damage.	
05/06/24	1	Aditya house	4th Floor lift front side Blue Filter.	10.05 am	11.30 am	Done	Filter and Stammer cleaning.	
	2	Aditya house	4th Floor Common Bathroom Blue Filter.	11.40 am	12.40 pm	Done	Stammer block.	
	3	Aditya house	3th Floor lift front side Blue Filter.	1.10 pm	1.50 pm	Done	Blue unit Filter Block.	
	4	Aditya house	5th Floor Common Bathroom Blue Filter.	2.50 pm	3.50 pm	Done	Filter and Stammer block.	
	5							
06/06/24	1	Aditya unassigned	Ac Not working	9:00 AM				
	2	B 401	" " "	10:15 AM	11:10 AM	Done	Repair.	
	3	C 107	" " "	11:00	5:00 PM	"	Cable repair	
	4	C 6th floor	" " "	11:00	5:00 PM	"	" "	
	5	Media studio		12:40 PM				

Date	Sl. no	Location	Complain	Com time	Att. time	Status	Indentification	Sing.
07/06/24	1	Aditya-2A 1st fl	Ac not working	10.10 am	11.40 am	Done		
	2	Harsha 3B fl	Ac not working	11.50 am	12.40 pm	Done		
	3	Harsha-26 W	Ac not working	1.40 pm	3.10 pm	Done		
	4	Harsha 2E fl	Ac not working	11.30 pm	4.25 pm	Done		
08/06/24	1	Aditya 4 PR	Ac not working	10.00 am	11.30 am	Done		
	2	" 6 PR	Ac not working	11.40 am	12.40 pm	Done		
	3	Aditya 2E	Ac not working	1.50 pm	2.40 pm	Done		
	4	Aditya 2B fl	Ac not working	3.10 pm	4.30 pm	Done		
09/06/24	1	Aditya 5E fl	Ac not working	9.40 am	10.50 am	Done		
	2	" 5E fl	Ac not working	11.10 am	12.30 pm	Done		
	3	Aditya 6E fl	Ac not working	1.40 pm	2.10 pm	Done		
	4	" 6E W	Ac not working	2.50 pm	3.20 pm	Done		
	5	" 6E W	Ac not working	3.40 pm	4.40 pm	Done		
10/06/24	1	Aditya house 3B	Ac not working	10.10 am	11.20 pm	Done		
	2	" " 3A1	Ac not working	11.30 am	12.40 pm	Done		
	3	" " 3A fl	Ac not working	1.50 pm	2.40 pm	Done		
	4	Aditya house 6PR	Ac not working	2.50 pm	4.10 pm	Done		
11/06/24	1	Harsha house 2A1	Ac not working	10.20 am	11.30 am	Done		
	2	" " 2A fl	Ac not working	11.40 am	1.10 pm	Done		
	3	" " 4B fl	Ac not working	2.30 pm	3.10 pm	Done		
	4	" " 4E fl	Ac not working	3.30 pm	4.40 pm	Done		
12/06/24	1	Harsha house-4E W	Ac not working	10.10 am	11.20 am	Done		
	2		Ac not working	11.30 am	12.40 pm	Done		
	3		Ac not working	1.40 pm	2.40 pm	Done		
	4		Ac not working	3.10 pm	4.30 pm	Done		
13/06/24	1		Ac not working	10.00 am	11.30 am	Done		
	2		Ac not working	11.40 am	12.50 pm	Done		
	3		Ac not working	2.10 pm	3.30 pm	Done		

DDMMYY

DDMMYY

Date	Sl no	Location	Complaints	Com time	Att time	Status	Indentification	Sing.
15/06/24	1	A-201	AC NOT cooling	9:20	10:10	Done	Repair	
	2	B-302	" " "	9:20	11:30	"	"	
	3	Guest House	Sound from AC	11:20	12:00	Done		
	4	Management	AC NOT cooling	11:40	2:00	"	check	
	5	Coloquium	" " "	2:30	3:10	"	check Trip	
	6	Alina 2B	AA AC Noise	3:40	5:00	"	Beang	
16/06/24	1	H-201	AC water leakage	11:00	11:30	"		
	2	D 506	AC NOT cooling	2:00	3:30	"		
	3	A-303	" " "	2:00	4:00	"		
	4	B 201	" " "	3:00	4:00	"		
17/06/24	1	A-405	AC NOT cooling	9:40	11:00	Done	Service	
	1	H-House 4B	" " "	10:00	12:00	Done	"	
	3	" " 3C	" " "	11:30	12:00	Done	"	
18/06/24	1	B-306	AC NOT cooling	9:50	2:30	Done		
	2	B 307	" " "	10:30	12:10	"		
	3	C 401	" " "	12:40	3:30	"		
	4	F 203	" " "	2:50	5:00	"		
19/06/24	1	Admin	AC NOT cooling	11:00	11:30	Done	Setting	
	2	B 404	" " "	3:40	4:30	"		
20/6	18	AC NOT cooling B101	AC NOT cooling	2:30	3:40	"		
24/6	E-204	C 204	" " "	4:00	4:30	"	McB Trip	
	2	C 205	" " "	4:00	4:30	"	" "	
24/6	1	A-305	AC Noise	11:40	12:30	Done	R-Setting	
	2	B-401	Sound	2:00	2:30		NOT found anything	
25/6	1	A-202	AC NOT cooling	9:50	11:00	Done		
	2	C-602	" " "	12:30	2:00	"		
	3	C 503	" " "	2:40	4:00	"		

ELECTRIC COMPLAINTS LOG BOOK

DDMMYYYY

Date	SL-NO	Location	Complain
01/12/23	1.	Aditya House 2A	Fan not working
	2.	" " 6E4	Light not working
	3.	" " 6A2	Light not working
	4.	" " 3E(IV)	Plug Point not Working
	5.	H-H 6B2	Fan Regulator Problem
	6.	H-H 3C2	Light not working
	7.	B-Block 1st Wash room	Light not working
02/12/23	1.	A-Block 402	Light not working
	2.	A-Block 306	Light not working
	3.	B-Block 507	Light not working
	4.	H-H 3C Wash room	Light not working
	5.	H-H 2A Lobby	Plug Point not working
	6.	H-H 1AC Wash room	Light not working
	7.	Samaya House 5th Wash room	Light not working
	8.	" " 203	Plug Point not working
	9.	D-Block 3rd Wash room	Light not working
03/12/23	1.	D-Block 204	Light not working
	2.	D-Block 407	Light not working
	3.	C-Block 3rd Corridor	Light not working
	4.	Aditya House 2D3	Switch not working
	5.	" " 3E Wash room	Light not working
	6.	" " 2E4	Fan not working
4/12/23	1.	Dhara	Mattar Power Problem
	2.	B-Block 401	Switch Board not work
	3.	B-Block 307	No Power
	4.	A-Block 103	Socket not working
	5.	H-H 6A3	Light not working
	6.	H-H 3E2	Fan not working
	7.	H-H 3B Wash room	Light not working
	8.	H-H 1E2	Plug Point not working

JANU

DDMMYYYY

Remarks	Identification	S-Time	E-Time	Sign
Done	Fan Bearing and Capacitor change	9:15pm		A. J.
Done	Light change 20W 1pc			
Done	Light change 20W 1pc			
Done	Socket change		11:45pm	
Done	Regulator change	12:00pm		
Done	Light change 1pc 20W		1:30pm	
Done	Light change 20W 1pc	3:00pm	4:30pm	
Done	Light change 20V 2pc	9:30pm		A. J.
Done	Light change 20W 1pc		11:30pm	
Done	Light change 20W 3pc	11:45pm	1:00pm	
Done	Light change 12W 1pc	2:00pm		
Done	Socket change		3:30pm	
Done	Light change 12W 1pc			
Done	Light change 10W 1pc	4:00pm		
Done	Socket change		5:00pm	
Done	Light change	5:15pm	5:45pm	
Done	Light change	10:00pm		A. J.
Done	Light change		11:15pm	
Done	Light change	11:30pm	12:00pm	
Done	Switch change	2:30pm		
Done	Light change		4:30pm	
Done	Fan Bearing change			
Done	Mattar Repairing	10:00pm	11:30pm	A. J.
Done	Switch change and Repairing	10:30pm		
Done	M.C.B. ON		12:00pm	
Done	Socket change	12:15pm	1:00pm	
Done	Light change	2:00pm		
Done	Capacitor change			
Done	Light change			
Done	Socket change		4:00pm	

JANU

DDMMYYYY

Date	Sl. No	Location	Complain	Remarks	Identification	S. Time	E. Time	Sign
5/12/23	1.	B. Block 1st Corridor	light not working	Done	light change 15W Panel	10:15pm		A/m
	2.	B. Block 2nd Corridor	light not working	Done	light change 18W Panel		11:45pm	
	3.	B. Block 4 Corridor	light not working	Done	light change			
	4.	Samaya 2nd	No Power	Done	M.C.B ON	1:30pm		
	5.	" 509 Washroom	light not working	Done	light change			
	6.	Samaya 2nd Washroom	light not working	Done	light change 10W 2PE		4:00pm	
6/12/23	1.	B. Block front Gurdan	light not working	Done	Power Repairing	10:15pm	11:00pm	A/m
	2.	Grnt no 1 Wall	light not working	Done	light change	11:20pm	11:50pm	
	3.	D. Block 407	light not working	Done	light change	12:15	12:45pm	
	4.	C. Block 6th	Plug Point not working	Done	Socket change	2:15pm		
	5.	C. Block 3rd Washroom	light not working	Done	light change		3:45pm	
7/12/23	1.	H.H 00.7	light not working	Done	light change	9:45pm		A/m
	2.	H.H 4c.2	Plug Point not working	Done	Socket change			
	3.	H.H 4D Wash room	light not working	Done	light change			
	4.	H.H 5A1	light not working	Done	light change		11:20pm	
	5.	Samaya 4th floor	No Power	Done	M.C.B ON	11:30	11:50pm	
	6.	Aditya House	RO Power Problem	Done	Repairing	12:00pm	3:00pm	
	7.	Gurdan	light not working	Done	light change	3:00pm	4:30pm	
8/12/23	1.	Grant House	Plug Point not working	Done	Socket change	10:15pm	10:45pm	A/m
	2.	D. Block Facalati	Socket not working	Done	Socket change	11:00pm		
	3.	D. Block 2nd Washroom	light not working	Done	light change		12:45pm	
	4.	B. Block 502	light not working	Done	light change	2:15pm		
	5.	B. Block 4th Corridor	light not working	Done	light change		3:00pm	
9/12/23	1.	Aditya House 6E5	light not working	Done	light change	10:00pm		A/m
	2.	" " 6B2	light not working	Done	light change			
	3.	" " 5C Washroom	light not working	Done	light change			
	4.	" " 3rd C.L	Plug Point not working	Done	Socket change		12:30pm	
	5.	Samaya " 4L7	Fan not working	Done	Capacitor change	2:00pm		
	6.	Samaya " 1st floor	No Power	Done	M.C.B ON			
	7.	Samaya " 6a	Plug Point not working	Done	Socket change		3:30pm	

Janart

Date	Sl-No	Location	Complain	Remarks	Identification	S-Time	E-Time	Sign		
10/12/23	1.	H.H 6D2	Fan Regulator Change	Done	Fan Regulator change	10:15pm	12:20pm	[Signature]		
	2.	H.H 6E23	light not working	Done	light change					
	3.	H.H 5E6	flap light not working	Done	Socket change					
	4.	H.H 4A2	light not working	Done	light change					
	5.	C. Block 5A	light not working	Done	light change					
	6.	H.H 1st @ Workshop	light not working	Done	light change				2:30pm	3:15pm
11/12/23	1	ADMITA Under Room	not working	Done	light change	11:00pm	12:00pm	[Signature]		
	2	Reomil Under Room	not working	Done	light change					
	3	Fom out work	not working	Done	light change					
	4	Socket Door PCB	not working	Done	Socket change				2:40pm	3:30pm
12/12/23	1	SARMAVA 6TH	NO POWER	Done	MCB ON	10:30pm	12:00pm	[Signature]		
	2	SARMAVA 303	SOCKET ON WORK	Done	Socket change					
	3	SARMAVA 102	MCB ON WORK	Done						
	4.	Hansa House 2EIV	Switch Board Not working	Done	socket and switch change.				12:30	
	5.	H.H 6C III	Fan Regulator Not working	Done	Regulator change.				3:10pm	4:20pm
13/12/23	1.	Boundary wall	some light not working	Done	Repair light.	11:20pm	1:45pm	[Signature]		
	2.	D Block 2nd Floor	Corridor strip light problem	Done	Light change.				2:50pm	3:15pm
	3.	A Block 3rd Floor	Corridor light and Workshop Light not working	Done	Light Damage and change.				3:00pm	4:30pm
	4.	NE Hostel	light Required For work	Done	Two Helogen Light fixed.				4:45pm	5:30pm
	5.	Aditya House TOP	Guinea power Required	Done	New MCB and power connection.				3:00pm	4:30pm
14/12/23	1.	B Block- 411A	Fan not working	Done	Capacitor change	10:30	11:40	[Signature]		
	2.	D Block IOAC Lab	Power board required	Done	16A Switch Socket fitting				12:00	1:05
	3rd JANUARY	Hansa house 1E IV	Tube light not working	Done	New Tube light fitting				2:20	3:45

DDMMYYYY

DDMMYYYY

Date	S.L. NO	Location	Complaint	Remarks	Identification	S. Time	E. Time	Sign
15.12.23	1.	Aditya House 5D III	Shocket not working	Done	Shocket changed	10:00 Am	10:30 Am	A
	2.	Harsha house 2E IV	Light Switch not working	Done	Switch changed	10:45 Am	11:10 Am	
	3.	B. Block 5.13	Shocket not working	Done	Shocket changed	11:20 Am	12:00 Pm	
	4.	Harsha house 1E IV	Tube light not working	Done	Tube light changed	2:30 Pm	3:10 Pm	
	5.	D Block 2nd floor	Panel light fuse	Done	New light fitting	3:20 Pm	4:45 Pm	
16.12.23	1.	Harsha house 4E VI	Switch Board broken	Done	Switchboard changed	9:45 Am	10:20 Am	A
	2.	B. Block 202	Fane not working	Done	Bearing changed	10:15 Am	11:45 Am	
	3.	Harsha House 2D III	washraon light not working.	Done	light changed	3:00 Pm	4:20 Pm	
	4.	A. Block 204	Switch Board Broken	Done	fix it properly	2:15 Pm	3:45 Pm	
	5.	C. Block 409	light not working	Done	New light fitting.	4:00 Pm	5:15 Pm	
	6.	Aditya House 4E II	Fan is not working, and switch board broken	Done	Fan Regulator changed and switch board fixed properly.	4:45 Pm	5:30 Pm	A
17.12.23	1.	A. Block 4th floor	Corridor light not working	Done	3. Pas light fitting	10:30 Am	11:45 Am	
	2.	Harsha House 6D II	Dim light Fuse	Done	Dim light changed	12:00 Pm	12:30 Pm	
	3.	D Block 6th Floor	Power Shocket required	Done	16A. Power Shocket Fitting.	2:30 Pm	3:25 Pm	
	4.	C Block Art Gallery	Power Board needed	Done	Power board fitting.	3:30 Pm	4:00 Pm	
	5.	Samaya house 4th Floor	Fan not working	Done	Fan changed.	4:40 Pm	5:30 Pm	

Janet

Janet

DDMMYYYY

Date	S.L. No	Location	Complaint	Remarks	Identification	Start time	End time	Sign
18.12.23	1.	Auditorium M.P. Hall	Tray light damage	Done	light changed	10:00 Am	11:00 Am	A
	2.	D Block Tap	letter connection damage	Done	wire changed	11:15 Am	12:30 pm	
	3.	A. Block 1st Floor	corridor light damage	Done	2 pcs LED Pannel changed	12:40 pm	1:30 pm	
	4.	Aditya House 3 E IV	Fan not working	Done	Fan changed.	2:30 pm	3:15 pm	
	5.	Samaya house kitchen	Switch board damage	Done	Switch Board changed.	3:30 pm	4:15 pm	
	6.	F. block 204 A	light damage	Done	LED Pannel light changed	4:20 pm	5:00 pm	
	7.	Harsha House 5 A II	Tube light damage	Done	light changed	3:45 pm	4:15 pm	
19/12/23	1.	Guest House	Power point Required	Done	wire damage, wire change	10:00 Am	11:30 Am	A
	2.	A. Block 1st Floor	light is blinking	Done	light changed	10:30 Am	11:10 Am	
	3.	C. Block Boutique	Power not available	Done	Repair.	11:30 Am	12:40 pm	
	4.	B. Block library	3 pcs light not working	Done	light changed.	11:30 Am	12:15 pm	
	5.	Harsha House G. Floor	Bathroom light not working	Done	light changed.	2:30 Am	3:00 pm	
	6.	Aditya House 2nd Floor	Fan is not working	Done	Beating changed.	3:15 pm	4:20 pm	
	7.	Harsha House 3 E III	light Fuse	Done	light changed.	3:15 pm	4:00 pm	
20,12.23	1.	B. Block 207	plug point damage	Done	Shocket changed	10:30 Am		A
	2.	B. Block. library	Power board required	Done	New wiring Board Installing		12:20 pm	
	3.	Harsha House lobby 6A	Fan not working	Done	Regulator changed.	2:30 pm	3:00 pm	
	4.	A. Block Tap	light fuse	Done	light changed.	3:20 pm	4:20 pm	

DDMMYYYY

Date	S.No	Location	Complain	Remarks	Identification	Start Time	End Time	Sign
21.12.23	1.	G.H.7 Block	Ro machine power Required	Done	New wiring connect.	10:00 Am	11:20 Am	
	2.	D block G.Floor Museum	Light connection Required	Done	New wiring and New spot light connection.	11:40 Am	2:20 Pm	
	3.	C Block 4th Floor	corridor Light Not working	Done	Two Led panel light change.	2:45 Pm	3:30 Pm	
	4.	C block 3rd "	Bathroom " " "	Done	Tube Light change.	3:15 Pm	4:00 Pm	
	5.	Hornby house G.F	Led panel Light Damage	Done	Light change 1pc	4:20 Pm	5:00 Pm	
22.12.23	1.	Guest House	Power Needed for workmen	Done				
	2.	Hight way Gate	Some light not work	Done	Repair.	9:30 Am	10:15 Am	
	3.	C Block Top	Later light (L) Not working	Done	Repair.	10:30 Am	11:00 Am	
	4.	Aditya House canteen	Some Two Light Not working	Done	Light change	11:30 Am	12:20 Am	
	5.	Aditya " 6th F.(601)	Tube light Not workin	Done	Light change	2:00 Pm		
	6.	" " 3rd F.(3E1)	Board Not working	Done	Switch Not working and change.			
	7.	" " 2nd F.(2D11)	Common Room Fan Not working	Done	Bearing change.		4:30 Am	
23.12/23	1.	Hornby house (1E11)	Night Light not working	Done	Light change.	9:40 Am		
	2.	" " (3C1)	Switch Board Not working	Done	Socket and switch change.		10:30 Am	
	3.	A block G.F	Two spot Light Damage	Done	Light change	11:00 Am		
	4.	" " 3rd F	Bathroom Light "	Done	" "		12:15 Pm	
	5.	D " 2nd Floor	Light point Light Not working	Done	Light change.	1:50 Pm	2:30 Pm	
	6.	C Block Fountain	Fountain not working	Done	wire Damage and wire change.	3:00 Pm	4:00 Pm	
24.12.23	1.	Aditya's house. SA II	light not working	Done	light changed.	10:00 Am	11:15 Am	
	2.	A. Block. Reception	light not working	Done	light changed.	11:30 Am	12:35 Pm	
	3.	C. Block 2nd Floor	Power point not working	Done	Repaired.	12:20 Pm	1:30 Pm	
	4.	A. Block 1st Floor	Light not working	Done	Light change.	12:00 Pm	1:15 Pm	
	5.	Aditya House 2nd F	Bathroom Light Not working	Done	Light change.	3:00 Pm	3:20 Pm	
	6.	Somaya House Basement	Some Light Needed	Done	8 Pcs Tube light connect.	3:40 Pm	5:00 Pm	

JANU

JANU

Date	Sl.No	Location	Complain
27/12/23	1.	School Gate	Power Not Available
	2.	Water panel	K. fountain MCB Tripping Problem
	3.	B block Library	Two panel Light Not working
	4.	B 1.G.F & Computer Lab	Some socket Not working
	5.	A block Seminar Hall	UPS power problem
	6.	C block G.F floor	Bolique power sp point problem
	7.	C " Badminton	Helogea light Not working
28/12/23	1.	Aditya House G.F	Bathroom Light Not working
	2.	" " 5th floor	Corridor Light Not working
	3.	Sanya House 3rd "	Bathroom fan Not "
	4.	Aditya " 5D11	Socket in Not working
29/12/23	1.	Hannah House 5EVI	Tuba light Not working
	2.	C block 2nd floor	power point " "
	3.	A " 1st floor	Corridor Light Damage
	4.	A " 4th "	Switch board Not working
	5.	Hannah House (4E11)	Fan making noise
30/12/23	1.	Aditya House (GDI)	Fan Regulation Not working
	2.	A block 408 A	No power in power board
	3.	Aditya H. 3rd. F	Corridor Light and washroom Light Not working
	4.	Sanya H. Back side	STP power Line Damage
	5.	C block G.F floor	SMPS power Required
	6.	Boundary Light	Some Light Not working and Holder are Lose in position
31/12/23	1.	Management HR cabin	Two panel Light Required
	2.	H.H Ground floor	Guinea and new machine power Required
	3.	C block 6th floor	Exhaust fan Not working
	4.	Main Gate	CC camera power problem
	5.	A block 1st floor	Washroom Light Not working

Remarks	Identification	Start Time	End Time	Sign
Done	Wise Damage and charge.	10:00Am	11:15Am	[Signature]
Done	Wise short circuit and charge wire	11:00Am	12:15Pm	
Done	Light charge.	12:30Pm		
Done	10 per socket charge.		1:40Pm	
Done	Repair.			
Done	Socket change.	2:20Pm	3:20Pm	
Done	Switch change.	3:40Pm		
			4:30Pm	
Done	Light charge.	10:30Am		[Signature]
Done	Two per light charge.		11:50Am	
Done	capacitor charge.	1:45Pm	2:20Pm	
Done	Socket charge	3:00Am	4:15Pm	
Done	Light charge.	11:00Am	11:30Am	
Done	Repair.	11:45Am	12:45Pm	[Signature]
Done	Light charge.	2:20Pm		
Done	Socket charge.		3:00Pm	
Done	Beaming charge.	4:11Pm	5:11Pm	
Done	Regulator charge.	10:30Am	11:00Am	
Done	power Board Repairing.	11:00Am	12:30Pm	[Signature]
Done	Light charge.	12:40Am	1:20Pm	
Done	Repair.	2:00Pm	3:15Pm	
Done		3:30Pm	4:15Pm	
Done	Repair.	4:30Pm	5:15Pm	
Done	Two new Led panel connection.	10:00Am	11:30Am	[Signature]
Done	new wiring connection.	11:45Am	12:20Pm	
Done	Repairing.	2:00Pm	3:20Pm	
Done	Repairing	4:00Pm	5:15Pm	
Done	Light charge.	12:45Am	1:10Pm	

DDMMYYYY

Date	Sl. No	Location	Complain	Remarks	Identification	Start time	End time	Sign
01/01/24	1.	B block 3rd Floor	Fan Light Remove	Done	1 fan, 4 lights remove	10:00Am	11:45Am	
	2.	F " 507	Light Not working	Done	Light change.	12:00Pm	12:20Pm	
	3.	Food court	4 pcs Light Damage	Done	Light change.	12:40Pm	1:15Pm	
	4.	A 102	1 Fan, 1 Light Not working	Done	capacitor change and Light change	2:00Pm	2:30Pm	
	5.	D block	Latches Not working	Done	MCB Damage and change the MCB	3:00Pm	3:45Pm	
	6.	R.G.S Gate	Short circuit	Done	Wire change.	4:00Pm	5:10Pm	
02/01/24	1.	Somaya canteen	Rodi makes machine problem	Done	Heater wire damage wire change.	10:15Am	11:00Am	
	2.	Aditya House (2B III)	Socket not working	Done	Socket change.	11:15Am		
	3.	" " (5D III)	Tube light Damage	Done	Light change.		12:00Am	
	4.	H.H. (5EV)	power Board not working	Done	Socket and switch change.	12:15Pm	1:00Pm	
	5.	Somaya House Back side	2 pcs Boundary Light Damage	Done	Light change.	2:30Pm	3:00Pm	
	6.	B block 307	Two Tube lights not working	Done	Light change.	3:40Pm	4:20Pm	
03/01/24	1.	D. Block Top	Power not available	Done	New power connected	9:45Am	11:30Am	
	2.	Harsha house 1st floor	Bathroom light not working	Done	light changed	11:40Am	12:15Pm	
	3.	D. Block reception	Some socket not working	Done	Socket changed	1:45Pm	2:15Pm	
	4.	Aditya house 4th floor	H.C.B. trip	Done	Repair	2:45Pm	3:30Pm	
	5.	B. Block 5th floor	corridor panel light not working	Done	light changed	3:45Pm	5:00Pm	
4/1/24	1.	Shaba	cable damage	Done	cable changed	10:00Am	12:00Pm	
	2.	A. Block Management	light damage	Done	1 pc. light changed	11:00Am		
	3.	A. Block Register office	2x2 light damage	Done	light change and a new one installed		1:20Pm	
	4.	Aditya house 2c II	light not working	Done	Two pcs. tube light change	2:15Pm	2:50Pm	
	5.	Lachet point	light not working	Done	Two light changed	3:15Pm	3:45Pm	
	6.	Harsha house 2B II	Power board not working	Done	Repair properly	4:00Pm	5:00Pm	

DDMMYYYY

DDMMYYYY

Date	Sl No	Location	Complaint	Remarks	Identification	Start Time	End Time	Sign.
5/1/24	1	NE Hostel Back Side	light requested for workers	done	Two Helogen light connected	0:30 Am	10:45 Am	
	2.	D. Block 4th Floor	wiring damage	done	wiring repairing	11:00 Am		
	3.	D. Block Food Court	light not working	done	light changed		1:30 Pm	
	4.	Harsha House 4B (Clus)	Switch not working	done	Switch changed	2:45 Pm		
	5.	Harsha House SE IV	Socket not working	done	Socket changed		3:20 Pm	
6.1.24	1	C. Block workshop	Tube light change	done	All tube light changed.	9:45 Am	10:30 Am	
	2.	A. Block reception	Spot light change	done	Some spot light change	10:45 Am	12:30 Pm	
	3.	Harsha House 1B II	Bathroom light not working	done	light changed	12:45	1:30 Pm	
	4.	Harsha house 6E II	B. Switch Board not working	done	Socket changed	2:30 Pm	3:00 Pm	
	5.	Harsha house 2C II	No power	done	power supply connection fix		4:15 Pm	
	6.	4. Block 3rd Floor	Exhaust Fan not working	done	Repairing	4:30 Pm	5:10 Pm	
7.1.24	1.	Harsha House 4E VI	Switch Board broken	done	Repair	10:00 Am	11	A/M
	2.	Harsha House 4E III	Night lamp fuse	done	Bulb changed		11:15 Am	
	3.	Samaya house 1st floor	Corridor light not working	done	3 pcs surface light change	11:30 Am	12:20 Pm	
	4.	Harsha house 2nd floor	Bathroom light not working	done	light changed	2:30 Pm	2:50 Pm	
	5.	Aditya house 4C (I)	Fan is not working	done	Bearing changed	3:00 Pm	3:45 Pm	
	6.	B. Block IT Room	one panel light requested	done	one panel light installed	4:00 Pm	4:40 Pm	

JANU




JANU



DDMMYYYY

DDMMYYYY

Date	Sl. No	Location	Complaint	Remarks	Identification	Start time	End time	Sign
8.1.24	1.	Harsha house 4 B #	cluster light not working	done	light change	9:30 Am	10:15 Am	}
	2.	B. Block. 1st Floor classroom	light change	done	All damage Tube light change	10:30 Am	12:20 Am	
	3.	A. Block Reception	Spot light change	done	10 pcs Spot light change	11:00 Am	12:45 Am	
	4.	G.H.I. Front.	H.C.B. required in Himax	done	32.A cable pole HCB Fixed	2:45 Pm	3:30 Pm	
	5.	D. Block Corner #	Himax Remove	done	Hi max Removed			
	6.	G.H.I. Front	cable damage	done	cable change and fixed			
9.1.24	1.	NE. Hostel Top	R.O. display	done	R.O. display fitting and wire dressing.	10:00 Am	11:30 Am	}
	2.	Main Gate	HCB damage	done	M.C.B change	11:40 Am	12:20 Pm	
	3.	D. Block Top	Reset MCB required	done	H.C.B Fixed	12:30 Pm	1:10 Pm	
	4.	Aditya House 3D III	Switch Board damage	done.	Socket changed	2:10 Pm		
	5.	Aditya House 5E #	Fan not working	done	capacitor changed		2:40 Pm	
	6.	Harsha House 1A I	Light not working	done	light changed	3:00 Pm	3:20 Pm	
	7.	Samaya 3rd Floor Corridor	Surface light not working	done	3 pcs Surface light fitting	3:40 Pm	4:20 Pm	
16.1.24	1.	B Block 2nd Floor classroom	light change	done	All damage Tube light change	10:00 Am		}
	2.	B. Block library	light not working	done	Three light changed		11:20 Am	
	3.	Dominos Pizza	light not working	done	Two light repairing	11:45 Am	12:20 Am	
	4.	Harsha House 3E D	Bathroom light not working	done	light changed	3:00 Pm	3:20 Pm	

Jan 24

Date	SLNO	Location	Complaint	Remark	Identification	Start time	End time	Sign
11.1.24	1	C. Block 4th Floor	corridor light damage	Done	4 LED panel light change	9:30 Am	11:30 Am	
	2	Samaya house 2nd Floor	Power supply disconnected	Done	power supply on	12:30 Am	12:15 Pm	
	3	Aditya House 6th Floor	light not working	Done	light changed	12:40 Pm	1:25 Pm	
	4	Samaya house 4th Floor	Fan doesn't working	Done	Bearing changed	2:00 Am	3:15 Pm	
	5	B. Block 203	Switch not working	Done	Switch changed	3:30 Pm	4:00 Pm	
	6	Harsha House SE II	light is broken	Done	light changed.	4:30 Pm	5:15 Am	
12.1.24	1	Harsha House 3A III	Charging point not working	Done	Socket changed	9:20 Am	9:50 Am	
	2	A. Block 1st Floor	Corridor light damage	Done	light changed	10:15 Am	11:00 Am	
	3	D. Block 2nd Floor Faculty room	Panel light damage	Done	light changed	11:15 Am	12:00 Pm	
	4	B Block. S07 c	Power Board not working	Done	Switch changed	12:20 Pm	1:00 Pm	
	5	Samaya Basement	light required for cleaning	Done	10 Tube light and two Helogen light connected.	2:00 Pm	3:30 Pm	
	6	D. Block 1st Floor	P.H.D LAB. one power board required	Done	New power Board connected	3:45 Pm	4:30 Pm	
	7	Bistro	Plug point not working	Done	Socket change	4:50 Pm	5:30 Pm	
13.1.24	1	D. Block Ground Floor	Power needed	Done	4 pes Socket connected	10:15 Pm	12:00 Pm	
	2	Harsha house 1c Lobby	Main Switch Board not working	Done	Switch Board Repaired	2:40 Pm		
	3	Harsha house 4 B.I.	Fan not working	Done	Fan capacitor changed		3:50 Pm	
	4	Aditya House 4 B	Washroom light not working	Done	light changed	4:10 Pm	5:00 Pm	

Date	Sl.No	Location	Complain	Remarks	Identification	Start Time	End Time	Sign
14/1/24	1.	Hanika House 3D11	Light Not working	Done	Light change.	10:30Am	11:00Am	
	2.	Dhaba	over power Needed	Done	Power Connection	1:30 Am	3:00 Pm	
15/1/24	1.	Hanika H. G.F	Bedroom Light not working	Done	Light change	0:40 Am	10:30 Am	
	2.	A M.P Hall	Camera power Needed	Done	New power connected.	10:45Am	1:30Pm	
	3.	Guest House Top	Meter Not working	Done	MCB change.	2:30 Pm	3:15 Pm	
	4.	D block G.F Popping	Tube light Not "	Done	Tube Light change.	3:20Pm	4:00Pm	
	5.	Aditya House 3D1	Board Not working	Done	Socket change	4:15Pm	4:45Pm	
	6.	G.H.I 3rd Floor	Fan Not "	Done	Repaired.	10:30Am	12:00Am	
	7.	C block 6th "	Exhaust fan not working	Done	Repaired	12:25:Am	1:45 Pm	
16/1/24	1.	B. block IT Room	power Board Needed	Done	Two power board connected	10:15 Am	11:45 Am	
	2.	Aditya.H. 3E11	Fan Not working	Done	Beasing change.	11:00 Am	12:15 Am	
	3.	Hanika.H. 3E1V	Fan Regulator broken	Done	Regulator change.	12:30 Pm	1:30Pm	
	4.	Aditya H. 2nd F	Charging point Not working	Done	socket change.	2:30Pm	3:20Pm	
	5.	Field light Area	Some light Not "	Done	Light change and repaired.	3:20 Pm	4:30 Pm	
	6.	A block Seminar Hall	power point Not working	Done	Socket change.	4:45Pm	5:20Pm	
17/1/24	1.	C block 4th floor	New Hall wiring Required	Done	New wiring Done	10:00Am	12:45Pm	
	2.	Main Gate	CC TV power Needed	Done				
	3.	Aditya House 4E11	to Bedroom Light Not working	Done	Tube light change.	11:45Am	12:30Am	
	4.	Hanika House 6B1	Fan Regulator Not working	Done	Regulator change.	2:30Pm	3:15 Pm	
	5.	A block 4th floor	corridor Light " "	Done	Light change.	3:20Pm	4:00 Pm	
	6.	D " 2nd " 201A	plug point Not working	Done	socket change.	4:20Pm	5:00Pm	
	7.	Highway Gate	2 lights Not "	Done	Repair.	5:30 Pm	6:20Pm	
18/1/24	1.	Aditya House Top	Guest MCB Damage	Done	MCB change.	9:15Am	10:20Am	
	2.	Hanika House 4B1	Light Not working	Done	one PC Tube light change	10:40Am		
	3.	Hanika " 3D11	Light " "	Done	" " " "		12:15Pm	
	4.	Aditya House 4D1	Bedroom Light Not working	Done	Light change.	12:30		
	5.	" " 2C11	Fan Not working cluster	Done	capacitor change.		1:45 Pm	
	6.	A block 3rd floor	corridor Light Not working	Done	2PCS Light change.	2:45Pm		
	7.	A " 5th "	Bedroom Light Not "	Done	Light change.		3:30Pm	
	8.	C " Lab	one light Damage	Done	light change.	3:45Pm	4:30 Pm	

Date	Sl. No	Location	Complain	Remarks	Identification	Start Time	End Time	Sign
19/1/24	1.	Aditya House 3E111	Led light and fan Not working	Done	Light change fan repair.	9:20 Am		[Signature]
	2.	Aditya " 5E1V	Light Not working	Done	Light change.		12:30 Am	
	3.	A,B Front Ground	Decoration Light Light flicking	Done		12:00pm	2:30 pm	
	4.	All campus Light	All light checked and Repaired	Done		2:45	4:00 pm	
	5.	C Block Fountain Light	MCB Damage	Done	New MCB connect.	4:15 pm	5:20 pm	
	6.	Hansa House Front	2 pcs Light Not working	Done	Repair.	5:30 pm	6:00 pm	
20/1/24	1.	Aditya House 3E111	Light Not working	Done	Light change.	11:30 Am	12:10 Am	
	2.	Main gate to school Gate	Some light and Ball bowl Broken	Done	Light and Ball change.	2:45 pm	4:30 pm	
21/1/24	1.	Aditya House 1E111	Light Not working	Done	Light change.	11:45 Am	12:15 Am	
	2.	Hansa " 3E11	*.fan " "	Done	capacitor "	3:00 pm	4:15 pm	
23/1/24	1.	Bar panel Room front	Display power needed	Done				
	2.	Aditya House (1A11)	Surface Light Not working	Done	Light change.	10:10 Am	10:40 Am	
	3.	D block 204	Fan Not working	Done	capacitor change.	10:50 Am	11:30 Am	
	4.	M.H 4th floor	Tailed light Not working	Done	Light change.	12:00 Am	12:45 pm	
	5.	Samsa Kitchen	Some light " "	Done	Light change.	1:00 pm	1:50 pm	
	6.	D block Back side	Some boundary light are Not working	Done	Light Repair and change.	2:30 pm	4:00 pm	
	7.	A block G.F	2 spot Light Damage	Done	Light change.	4:15 pm	5:45 pm	
13/1/24	1.	B Block Top	RO machine MCB Damage	Done	Repair	10:10 Am	11:00 Am	
	2.	Samsa 2nd floor	Corridor Light Not work	Done	Light change.	11:15 Am	12:30 pm	
	3.	Hansa House 6th f.	Bedroom Light " "	Done	" "	12:40 pm	1:15 pm	
	4.	Aditya House Reception	One panel light Damage	Done	Light change	2:30 pm	3:00 pm	
	5.	D block front	Lamp post Light " "	Done	Light " "	3:15 pm	3:45 pm	
	6.	B " 1st floor	one pc Corridor Light	Done	Light " "	4:00 pm	4:30 pm	
	7.	Hansa House 5th floor	Not working					
	7.	Hansa House 5th floor	Dist Tailed light fuse	Done	light change	4:45 pm	5:20 pm	

Date	Sl. No	Location	Complaint	Remark	Identifications	Start time	End time	Sign
24.1.24	1	A Block 210	light does not working	Done	light changed	9:40 pm	10:15 pm	[Signature]
	2	Aditya house 6E IX	Fan does not working	Done	Bearing changed	10:00 pm	12:10 pm	
	3	D. Block 6th Floor	Power Board required	Done	Ne wiring done	11:20 pm	3:30 pm	
	4	Aditya House 2C(ii)	Charging Point not working	Done	Socket changed	4:00 pm	4:30 pm	
	5	A. Block M.P. Hall	Power needed	Done	Power connected	2:30 pm	5:20 pm	
	6	Harsha house 5B II	Bathroom light not working	Done	light changed	5:15 pm	5:40 pm	
25.1.24	1	B. Block 102	Fan does not working	Done	Regulator changed	10:30 pm	10:50 pm	[Signature]
	2	Aditya House 3D I	light doesn't working	Done	light changed	11:20 pm	11:45 pm	
	3	Main Gate	Some of boundary light does not working	Done	H.C.B. changed	10:30 pm	12:20 pm	
	4	Guest House Front	Power socket needed	Done	Power socket connected	2:00 pm	3:10 pm	
	5	Aditya House 6D II	Fan doesn't working	Done	Bearing changed	3:15 pm	4:00 pm	
	6	G. Block	Motor Starter doesn't working	Done	Starter changed	4:15 pm	5:20 pm	
26.1.24	1	Aditya House 3D(i)	light doesn't working	Done	light changed	9:45 pm	10:15 pm	[Signature]
	2	C. Block Top	Halogen doesn't working	Done	Halogen changed	10:30 pm	11:50 pm	
	3	Harsha house 1B III	Fan doesn't working	Done	Bearing changed	12:30 pm	1:30 pm	
	4	Samaya House 3E IV	Night lamp fused	Done	Night lamp changed	2:45 pm	3:15 pm	
	5	Shaba	Motor power needed	Done	Power socket connected	3:20 pm	5:00 pm	

Date	S.L. No	Location	Complaint	Remark	Identification	Start time	End time	Sign
29.1.24	1.	Samaya House Kitchen	Switch Board not working	Done	Shocket changed	10:21Am	10:50Am	
	2.	A Block 4th Floor	corridor light not working	Done	light changed	11:15Am	12:10pm	
	3.	D Block 1st Floor	Profile light driver does not working	Done	driver changed	12:30pm	1:01pm	
	4.	Aditya Top	M.C.B doesn't working	Done	M.C.B changed	2:30pm	3:45	
	5.	Samaya House 3 B IV	Fan doesn't working	Done	Regulator changed	4:15pm	5:20pm	
30.1.24	1.	B. Block Chemistry Lab	light doesn't working	Done	light change	9:40Am	10:00Am	[Signature]
	2.	Guest House 1st Floor	light doesn't working	Done	light changed	10:15Am	11:00Am	
	3.	A. Block H.P. Hall	Two Shocket doesn't working	Done	Shocket changed	11:20Am	12:15pm	
	4.	Aditya House Dinning Hall	one light doesn't working	Done	light changed	1:45pm		
	5.	Aditya House Kitchen	one tube light does not working	Done	light changed		3:30pm	
	6.	B. Block 3rd Floor	Bathroom light does not working	Done	light changed	3:45pm	5:15pm	
31.1.24	1.	Aditya House 6 B I	light doesn't working	Done	light changed	10:15Am		[Signature]
	2.	Aditya House 5 C II	Plug point not working	Done	Shocket changed			
	3.	Aditya House 5th Floor	Washroom light does not working	Done	light changed		12:10pm	
	4.	B. Block 403 B	light doesn't working	Done	light changed	12:15pm	1:30pm	
	5.	Harsha House 6 B I	light not working	Done	light changed	2:40Am	3:00pm	
	6.	B. Block 5 II	light not working	Done	light changed	3:40pm	5:20pm	

Date	Sl.No	Location	Complaint	Remark	Identification	Start time	End time	Sign
01.02.24	1	B. Block Ground Floor	Bathroom light doesn't working	Done	light changed	10:30 Am	11:00 Am	[Signature]
	2	Harsha House 4 B	washroom light not working	Done	light changed	11:20 Am	12:00 Pm	
	3	D. Block Stair	Surface light doesn't working	Done	3 pes Surface light changed	1:31 Pm	3:05 Pm	
	4	B. Block Incubator	Some socket doesn't working	Done	12 pes GA socket changed	2:30 Pm	4:00 Pm	
	5	A. Block Seminar Hall	Switch Board Broken	Done	wire dressing and switch board repaired	4:15 Pm	5:30 Pm	
02.02.24	1	Harsha House 1 E II	Night lamp doesn't working	Done	Night lamp changed	9:45 Am	10:20 Am	[Signature]
	2	Aditya House 5 D III	light doesn't working	Done	light change	10:30 Am	10:51 Am	
	3	Harsha House 6 B I	Fan Regulator Damage	Done	Regulator changed	2:40 Pm	2:15 Pm	
	4	A. Block 6th Floor	Corridor and wash room light doesn't working	Done Done	Corridor light changed washroom light changed	3:20 Pm	4:45 Pm	
	5	S.T.P	MCB needed for Motor	Done	Double pole MCB installed	4:00 Am	5:15 Pm	
	6	B. Block Ground Floor	Spot light wiring needed	Done	New wiring for spot light	11:00 Am	3:15 Pm	
03.02.24	1	C. Block Ground Floor	Powerboard needed for Machine	Done	Power Board connected	9:51 Am	11:00 Am	[Signature]
	2	Water pannel	Power board need for water flow meter	Done	Power Board installed	11:15 Am	12:10 Am	
	3	D Block Back Side	Power Board needed for water flow metter.	Done	Two power board installed	12:15 Pm	1:30 Pm	
	4	A. Block Top	Helogen light doesn't working	Done	light changed	2:40 Pm	3:20 Pm	
	5	D. Samaya House 1st Floor	Corridor light doesn't working	Done	light changed	3:30 Pm	4:50 Pm	



DDMMYYYY

DDMMYYYY

Date	Sl No	Location	Complaint	Remark	Identification	Start time	End time	Sign
4.2.24	1	Harsha House 3E II	Fan doesn't working	Done	Bearing changed	9:45 Am	10:00 Am	Amm
	2	Aditya House 4E II	Switch Board Broken	Done	Repaired	10:05 Am	10:30 Am	
	3	Security Camp taking gash	Tube light doesn't working	Done	1 Six Tube light fitting	11:00 Am	1:15 Pm	
	4	Main Gate Glow Sign	Driver damage	Done	Driver changed	2:30 Pm	3:00 Pm	
	5	Samaya Basement	light required for painting	Done	12 pcs Tube light fitting	3:20 Pm	4:20 Pm	
5.2.24	1.	Harsha House 3E VI	light doesn't working	Done	Tube light changed	10:10 Am	10:30 Am	Amm
	2.	Samaya House TOP	Ro Machine MCB Damage	Done	MCB change.	10:40 Am	12:30 Am	
	3.	Aditya " Bldg 4B	Bathroom light not working	Done	light change.	2:30 Pm		
	4.	" " 107	Fan Not working	Done	Bearing change.			
	5.	" " 5A2	Room Light Not working	Done	Light change.			
	6.	" " 3EVI	Fan Not working	Done	capacitor change		4:45 Pm	
6.02.24	1.	Harsh House 3D III	Board Not working	Done	socket change.	10:00 Am		Amm
	2.	" " 5B 1	Play Point not Working	Done	Socket change			
	3.	" " 4E 1	light not Working	Done	light change			
	4.	" " 4E Wash-room	light not Working	Done	light change		12:30 Pm	
	5.	Samaya House 2nd floor	No Power	Done	MCB on	3:45 Pm	4:00 Pm	
7.02.24	1.	Aditya House 2A m	sound not coming	Done	change	9:30 Am		Amm
	2	E 206 Fan not coming	fan not coming	Done	capacitor change			
	3	A 8 413	NO power	Done	MCB on			
	4	Aditya House 4C 2	Play Point not Working	Done	Socket and Switch change			
	5	" " 5B m	" " " "	Done	Socket change			
	6.	" " 5E Wash-room	light not Working	Done	light change		12:45 Pm	
	7.	B Block 2nd	light not Working	Done	light change		2:00 Pm	
	8.	Main Gate Wall	Relax light ..	Done	light change		2:45 Pm	

Date	Sl. No	Location	Complain	Remarks	Identification	S. Time	E. Time	Sign
8/02/24	1.	B. Block Top	Power Problem	Done	Repairing	9:20 Am	10:30 Am	}
	2.	D. " 2nd Wash room	light not working	Done	light change	10:45 Am	11:10 Am	
	3.	B. Block 5th Corridor	light not working	Done	light change	11:20 Am		
	4.	B. " 405	Plug Point not working	Done	Socket change		12:30 Am	
	5.	B. " 503	No Power	Done	M.C.B on	2:15 Pm	2:40 Pm	
	6.	Guardan light	light not working	Done	Change and Repairing	3:15 Pm	4:15 Pm	
9/02/24	1.	H.H 6 E 5	Plug Point not working	Done	Socket change	9:40 Pm		}
	2.	H.H 6 C 2	Board not working	Done	Repairing			
	3.	H.H 7 B 1	Fan Regulator not working	Done	Regulator change			
	4.	H.H 2 A 1	Board not working	Done	Switch change		11:20 Am	
	5.	Saraya 5th Wash room	light not working	Done	light change	11:45 Am	12:15 Am	
	6.	Aaditya 2nd B	No Power	Done	M.C.B on	12:30 Pm	2:00 Pm	
	7.	" 4 C 2	Power not working	Done	Socket change	2:20 Pm		
	8.	" 4 E 5	light not working	Done	light change			
	9.	" 3 B 2	light not working	Done	light change		4:00 Pm	
10/02/24	1.	Aditya House Top	Grease Power Problem	Done	Repairing	9:20 Am		}
	2.	" " 2 A 1	Fan Regulator Problem	Done	Regulator change			
	3.	" " 2 C 2	Plug Point not working	Done	Switch change			
	4.	" " 3 D "	light not working	Done	light change		11:45 Am	
	5.	B. Block 306	light not working	Done	light change	12:30 Pm		
	6.	B. Block 309	light not working	Done	light change		1:20 Pm	
	7.	B. Block 2nd Wash room	light not working	Done	light change	3:00 Pm	4:35 Pm	
11/02/24	1.	Saraya House 509	light not working	Done	light change	10:30 Am		}
	2.	" " 304	Socket not working	Done	No Power M.C.B on		10:45 Am	
	3.	H.H on Corridor	light not working	Done	light change	11:00 Am		
	4.	H.H 1C Wash room	light not working	Done	light change			
	5.	H.H 2 E 4	Plug Point not working	Done	Socket change			
	6.	H.H 4 B 2	Fan Regulator not working	Done	Regulator change			
	7.	H.H 5 D Lobby	light not working	Done	light change		1:30 Pm	
	8.	Guest House 1st floor	light not working	Done	light change	2:00 Pm	4:15 Pm	
	9.	Guardan	light not working	Done	Repairing	4:30 Pm	5:25 Pm	

Date	Sl. No	Location	Complain	Remarks	Identification	C. Time	E. Time	Sign
12/02/24	1.	B. Block 2nd	no Power	Done	MCB on	10:10pm	10:45pm	A
	2.	H.H 30 Wash room	light not working	Done	light change	11:10pm		
	3.	H.H 2A1	Socket not working	Done	Socket change		11:45pm	
	4.	Aditya 5E Washroom	light not working	Done	light change	12:10pm	12:20pm	
13/02/24	1.	D. Block 4th Washroom	light not working	Done	light change	10:00pm	11:30pm	
	2.	Dhaka	Mortar not working	Done	Repairing	10:30pm	12:20pm	
	3.	Aisto Corridor	Socket not working	Done	Socket change	11:15pm	1:00pm	
	4.	Harsh House 5C Washroom	light not working	Done	light change	2:20pm		
	5.	" " 5E3	Plug Point not working	Done	Socket change			
	6.	" " 2E2	light not working	Done	light change		3:45pm	
14/02/24	1.	Aditya House 6D2	Power not working	Done	Switch change	10:00pm		
	2.	" " 6E5	light not working	Done	light change			
	3.	" " 5B Lobby	Plug Point not working	Done	Socket change			
	4.	" " 3C Washroom	light not working	Done	light change		12:15pm	
	5.	H.H 2nd Warden Room	light not working	Done	light change	12:20pm		
	6.	H.H 3C1	Plug Point not working	Done	Socket change			
	7.	H.H 1C Washroom	light not working	Done	light change		1:30pm	
	8.	D. Block 307	light not working	Done	light change	2:20pm	3:15pm	
	9.	A. Block 401	Board Spoke	Done	Repairing	3:20pm	4:45pm	
15/02/24	1.	B. Block 3rd floor	no Power	Done	MCB on	9:20pm	10:40pm	A
	2.	H.H 2B1	light not working	Done	light change	10:45pm	11:10pm	
	3.	Samaya 2nd	No Power	Done	MCB on	11:30pm	11:45pm	
	4.	Samaya Restaurant	Mortar Power Mashed	Done	Power Connection	12:15pm	1:45pm	
	5.	D. Block front 6A Corridor	light not working	Done	light change and Repairing	3:00pm	4:15pm	
16/02/24	1.	D. Block locality	Plug Point not working	Done	Switch change	10:30pm	11:15pm	A
	2.	B. Block "	Socket not working	Done	Socket change	10:45	11:30pm	
	3.	H.H 4AA Washroom	light not working	Done	light change	11:45pm	12:30pm	
	4.	B. Block Plot	Mortar not working	Done	Repairing	1:15pm	3:00pm	
	5.	Samaya House 3rd	no Power	Done	MCB on	3:45pm	4:15pm	
	6.	H.H 2E6	Plug Point not working	Done	Socket change	5:00pm	5:30pm	

Date	Sl. No	Location	Complain	Remarks	Identification	B. Time	E. Time	Sign
17/02/24	1.	Harsh House 2C1	light not working	Done	light change	10:15pm		
	2.	" " CA Washroom	light not working	Done	light change		11:00pm	
	3.	Samaya 51F	light not working	Done	MSB on	2:45pm	3:40pm	
	4.	Gurdon	light not working	Done	light change	4:30pm	5:20pm	
19/02/24	1.	H.H 1C Wash room	light not working	Done	light change	10:15pm		
	2.	H.H 2E 2	light not working	Done	light change			
	3.	H.H 2nd Warden Room	light flicks	Done	light change			
	4.	HH 2D 3	Plug Point not working	Done	socket change		1:00pm	
	5.	B. Block 4th locality	Power Connection	Done	Power Connection	9:20	10:00pm	
	6.	A. Block 401	Board Spark	Done	Socket change	10:10pm	10:50pm	
20/2/24	1.	Aditya House 2 D III	Switch Board not working	Done	Switch Socket changed	9:30 AM	9:55 AM	
	2.	Samaya House 709	Tube light doesn't working	Done	Two tube light changed	10 AM	10:25 AM	
	3.	A. Block 3rd Floor	Corridor light not working	Done	light changed.	10.		
	4.	A. Block Ground Floor	Panned light not working	Done	light changed			
	5.	Samaya House 3 B II	Fan doesn't working	Done	Bearing changed			
	6.	Harsha House 1 E II	Switch Board not working	Done	Switch Socket changed.			
21.2.24	1	B. Block 103	Fan doesn't working	Done	Regulator changed			
	2.	Aditya House 4 C (I)	light doesn't working	Done	light changed			
	3.	NE Hostel.	light required for work	Done	Three Two light connected			
	4.	Harsha House 5 B III	Fan doesn't working	Done	capacitor changed			
	5.	C. Block 3rd floor	light doesn't working	Done	light changed			
	6.	Harsha House 4 C II	dim light Fuse	Done	Bulb changed			

Date	Sl. No	Location	Complaint	Remark	Identification	Start time	End time	Sign
22.2.24	1.	D. Block 303	light doesn't working	done	light changed			
	2.	Harsha House 3 D II	Bathroom light doesn't working	done	light changed.			
	3.	Bamaya House 2nd Floor	Corridor light not working	done	light changed			
	4.	N.E Hostel. 6th Floor	Fan doesn't working	Done	New Fan installed	7:15 PM	7:30 PM	
	5.	Aditya House 3 E II	light doesn't working	done	light changed.			
23.2.24	1.	C. Block 3rd Floor	Board Not working	Done	Board Repair.	9:30 AM	9:50 AM	
	2.	B block 6th Floor Lab	Some socket problem	Done	Socket change.	10:00 AM	11:30 AM	
	3.	Aditya House 4th Floor	power Board Not working	Done	Socket change	11:40 AM	12:00 PM	
	4.	B block 1st Floor corridor	Light Not working	Done	Light change	12:10 PM	12:30 PM	
	5.	B block 303	socket not working	Done	Socket change	12:40 PM	1:00 PM	
	6.	B block 407	Loose socket	Done	Repair	1:00 PM	1:10 PM	
	7.	B block 502	Switch Board Damage	Done	Repair	2:00 PM	2:30 PM	
	8.	B block 507	Light Not working	Done	Light change	2:40 PM	3:00 PM	
24.2.24	1.	A block 302	Socket Not working	done	Socket change			
	2.	A block 401	socket " "	Done	" "			
	3.	D block Seminar Hall	socket " "	Done	" "			
25.2.24	1.	Harsha House (2E II)	Socket Not working	Done	" "			
	2.	Harsha " E cluster	Socket " "	Done	" "			

DDMMYYYY

DDMMYYYY

Date	Sl. no	Location	Complain	Remarks	Identification	Start Time	End Time	Sign
26.2.24	1.	C block 306	Needed projection power	Done				
	2.	C block 605	" " "	Done				
	3.	C block 601	" " "	Done				
	4.	B block 306	" " "	Done				
	5.	A block 102	panel Light Location change	Done	4 pcs panel light location change.			
	6.	B block 1st floor Lab	Needed projection power	Done				
	7.	D block 5th floor	Some Bulb not working	Done	Light change			
	8.	F " 5th "	Some Bathroom Light not working	Done	Light change.			
27.2.24	1.	D block 4th floor	Some Bathroom Light not working	Done	" "			
	2.	F block " floor	Some Bathroom Light not working	Done	Light change			
	3.	D block 3rd floor	Bathroom Light not working	Done	Light change.			
	4.	Main Gate to S. Gate	5 pcs Boundary Light not working	Done	Repair and change.			
	5.	D.E.F block All Fire Cylinder	All Expire Fire Extinguisher removed	Done				
28.2.24	1.	B. Block ground floor	Bathroom Board Broken	Done	Switch changed.			
	2.	B. Block B.C.S.E.	No power in computer board	Done	Power Supply ON			
	3.	Aditya.H. 4EIV	Tube light not working	Done	Light change.			
	4.	" " 4CII	" " " "	Done	" "			
	5.	" " 4CII	Fan Regulator not working	Done	Regulator change.			
	"	" " 6AII	Toiled bulb " "	Done	Light change.			

A

PLUMBING LOG BOOK

Date	Sl. No	Location	Complain	Com. Time	Att. Time	Remarks	Indentification	Siny.
12/12/24	①	Achya house	shower broken	10:10	10:45	Done	changed	
	②	Samaya 2nd floor	shower broken	12:30	12:50	Done	changed	
	③	C block and	angle cock	2:30	2:45	Done	changed	
13/12/24	①	D block	wash pipe	10:15	10:25	Done	clear	
	②	C block	pipe line sum	12:00	12:30	Done	clear	
	③	Achya and	angle cock	2:45	3:00	Done	changed	
	④	GH	Drinking water not	4:10	4:45	Done	selected	
14/12/24	①	Achya and floor	H To set not	9:15	9:25	Done	new H To set	
	②	HH 3rd floor	flush not working	12:00	12:20	Done	repairing	
	③	HH 4th floor	angle cock	3:45	4:15	Done	changed	
15/12/24	①	Achya 2nd floor	angle cock	10:05	10:25	Done	changed	
	②	Samaya house	leakege	12:30	1:00	Done	problem selected	
	③	C block	leakege	2:45	3:10	Done	problem selected	
	④	D block	better tap sum	4:45	5:15	Done	clear	
16/12/24	①	A block	connection pipe	10:00	10:30	Done	changed	
	②	b block	wash pipe	12:30	12:45	Done	changed	
	③	Achya house	shower not	1:00	1:30	Done	property not changed	
17/12/24	①	Samaya house	cock not	10:00	10:20	Done	already the water	
	②	Achya and floor	shower not	12:00	12:25	Done	already water	
	③	C block	angle cock	12:35	12:45	Done	changed	
	④	D block	angle cock			Done	changed	
18/12/24	①	A block	Flush not working	10:45	10:55	Done	repairing	
	②	D block	H To set not working	2:30	2:45	Done	repairing	
	③	HH 5th floor	NO HOT water	4:10	4:45	Done	property not water	
19/12/24	①	HH top	gripper	10:05	10:45	Done	clear	
	②	HH 1st floor	angle cock	12:30	12:45	Done	changed	
	③	Achya and floor	shower broken	2:30	2:45	Done	changed	

Date	Sl. no	Location	Complain
12/20/24	(1)	Samaya house	only connection
	(2)	" "	" "
	(3)	" "	" "
12/21/24	(1)	Samaya house	basin gum
	(2)	" "	" "
	(3)	Aditya house	angle cock
	(4)	Samaya house	angle cock
12/22/24	(1)	Samaya	filler cock
	(2)	Aditya house	angle cock
	(3)	C block	basin gum
	(4)	A block	tap broken
12/23/24	(1)	H.A	hilo set
	(2)	" "	" "
	(3)	Aditya house	bottle tap gum
24/12/24	(1)	B block	angle cock
	(2)	Hexamsh	not hot water
	(3)	Samaya house	bottle gum
	(4)	Aditya	connection pipe
25/12/24	(1)	H.A	not hot water
	(2)	Aditya house	connection pipe
	(3)	A block	connection pipe
26/12/24	(1)	Aditya	filler cock
	(2)	Samaya	connection pipe
	(3)	H.A	tap broken
	(4)	A block	connection pipe
	(5)	Aditya	angle cock

Com-time	Att-time	Remarks	Indentification	Long
9:45 Am	12:00 pm	Done	clean	
2:30 pm	3:30 pm	Done	clean	
3:40 pm	6:10 pm	Done	fitting	
10:10 Am	10:25 Am	Done	clean	
10:45 Am	11:10 Am	Done		
11:25 Am	12:00 pm	Done	change	
4:30 pm	5:00 pm	Done	change	
9:30 Am	9:50 Am	Done	change	
11:20 Am	11:45 Am	Done	change	
2:30 pm	2:45 pm	Done	clean	
4:45 pm	5:20 pm	Done	repairing	
10:45 Am	11:00 Am	Done	change	
12:00	12:30 Am	Done	change clean	
4:45 pm	5:30 pm	Done		
9:15 Am	9:45 Am	Done	repairing	
12:00 pm	12:30 pm	Done	hot running	
2:30 pm	2:45 pm	Done	clean	
4:15 pm	4:45 pm	Done	change	
10:45 Am	11:00 Am	Done	hot running	
12:30 pm	12:45 pm	Done	change	
3:30 pm	4:00 pm	Done	change	
10:15 Am	10:30 Am	Done	repairing	
12:45 pm	1:10 pm	Done	change	
2:00 pm	2:30 pm	Done	repairing	
3:45 pm	4:20 pm	Done	change	
4:30 pm	5:20 pm	Done	change	

Date	Sl. no	Location	Complain
27/12/23	①	Adi Hanisha (ii)	water not working
	②	" "	water not working
	③	Achya house	angle cock
	④	Samaya (iv)	angle cock
28/12/24	①	Samaya house	basin gun
	②	" "	NLV end working
	③	Achya house	water leakage
	④	H H 1st	Hot water not working
29/12/24	①	Achya house	basin gun
	②	Samaya house	connection pipe
	③	" "	connection pipe
	④	A block	connection pipe
31/12/24	①	A block	system block
	②	Achya	flush not working
	③	H H 1st	water leakage
2/1/24	①	B block	Drinking water not working
	②	Achya 2nd	connection pipe
	③	Achya 4 b	Hot water not working
	④	D block	angle cock
3/1/24	①	Achya house	connection pipe
	②	Samaya house	angle cock
	③	H.H	flush not
	④	A block 1st	flush not working
4/1/24	①	Samaya house	system block
	②	A block	angle cock
	③	D block	connection pipe
	④	H H 1st	Drinking water not

Com-time	Att-time	Remarks	Indentification	Serv.
9:20 Am	9:30 Am	Done	Solved	
9:50 Am	10:00 Am	Done	Solved	
12:00 Pm	12:20 Pm	Done	change	
4:40 Pm	5:00 Pm	Done	change	
		Done		
10:00 Am	10:10 Am	Done	clean	
10:30 Am	1:20 Pm	Done	complete	
2:30 Am	2:50 Pm	Done	Solved	
4:10 Pm	4:30 Pm	Done	Hot water 1st floor	
		Done		
9:45 Pm	10:00 Am	Done	clear	
11:10 Am	11:30 Am	Done	change	
12:30 Pm	12:45 Pm	Done	change	
4:20 Pm	4:40 Pm	Done	change	
		Done		
10:15 Am	10:40 Am	Done	clear	
12:00 Pm	12:40 Pm	Done	repairing	
2:30 Pm	3:10 Pm	Done	Solved	
9:50 Am	10:10 Am	Done	Drinking is solved	
11:15 Am	11:30 Am	Done	change	
1:50 Pm	2:20 Pm	Done	Hot water All	
4:45 Pm	5:10 Pm	Done	change	
10:10 Am	10:20 Am	Done	change	
11:10 Am	11:30 Am	Done	change	
12:30 Pm	12:50 Pm	Done	repairing	
4:05 Pm	4:45 Pm	Done	repairing	
9:30 Am	9:50 Am	Done	clear	
11:30 Am	11:50 Am	Done	change	
4:20 Pm	4:40 Pm	Done	change	
4:50 Pm	5:00 Pm	Done	Solved	

Date	Sl. No	Location	Complain	Com time	End time	Remarks	Job/Specification	Eng
05/13/24	①	Achya house	connection pipe	9:40 Am	10:00 Am	Done	changed	
	②	Samaya house	angle cock	10:30 Am	10:30 Am	Done	changed	
	③	H. H	Basin Jun	1:30 Pm	1:50 Pm	Done	clear	
	④	A block	Basin Jun	4:00 Pm	4:20 Pm	Done	clear	
06/13/24	①	A block	angle cock	11:40 Am	12:00 Pm	Done	change	
	②	A block	flush not	12:00 Pm	1:00 Pm	Done	repairing	
	③	B block	connection pipe	2:30 Pm	2:50 Pm	Done	changed	
	④	H. H	System Jun	4:45 Pm	5:30 Pm	Done	repairing	
07/18/24	①	Aditya house	flush not	9:30 Am	10:00 Am	Done	repairing	
	②	H. H	Hot water not	11:30 Am	12:00 Pm	Done	Hot water clear	
	③	Samaya house	angle cock	3:30 Pm	3:45 Pm	Done	change	
	④	Aditya house	connection pipe	5:00 Pm	5:20 Pm	Done	New pipe	
08/13/24	①	D block	Flush July not	11:20 Am	12:00 Pm	Done	repairing	
	②	D block - 3rd	basin flush plat not	2:30 Am	2:50 Pm	Done	New plate	
	③	D block	bottle tap not	4:00 Pm	4:10 Pm	Done	New - bottle tap	
	④	" "	Hot set not	4:45 Pm	5:30 Pm	Done	New - Hot set connection	
09/12/24	①	B block	bottle tap	9:30 Am	9:50 Am	Done	clear	
	②	" 4 End floor	bottle tap not	11:00 Am	11:30 Am	Done	New bottle tap	
	③	" "	Hot set not	3:00 Pm	3:30 Pm	Done	changed	
	④	B block	angle cock	4:45 Pm	5:00 Pm	Done	changed	
10/18/24	①	Samaya house	flush not working	9:30 Am	9:50	Done	repairing	
	②	Aditya house	angle cock not working	11:30 Am	11:40 Pm	Done	changed	
	③	A block	connection pipe not	12:00 Pm	12:20 Pm	Done	changed	
	④	H. H 3rd floor	flush not working	2:30 Pm	2:50 Pm	Done	repairing	
	⑤	D block	Hot set not working	3:40 Pm	3:50 Pm	Done	repairing	
	⑥	C block	pipe connection	4:20 Pm	4:30 Pm	Done	New pipe connection	
	⑦	Alexand	Hot Hot water	5:20 Pm	5:40 Pm	Done	All connections Hot water	

Date	S.no	Location	complain	com time	end time	Remark	Identification	isng
11/3/24	①	Aditya house	Hot water breaker	9:30 Am	9:40 Am	Done	change	
	②	Samaya house	angle cock not	11:20 Am	11:40 Am	Done	changed	
	③	C. block	pipe connection.	11:50 Am	12:30 pm	Done	New connection	
	④	D block	flush not working	2:40 pm	3:20 pm	Done	repairing	
	⑤	H. H	connection pipe	4:00 pm	4:20 pm	Done	New pipe	
12/3/24	①	A block	connection pipe	10:00 Am	10:20 Am	Done	New pipe	
	②	b block	angle cock	10:40 Am	11:00 Am	Done	changed	
	③	H. H	Mixture not working	2:20 pm	3:00 pm	Done	repairing	
	④	Aditya house	shower not working	4:20 pm	4:40 pm	Done	New shower	
	⑤	Samaya house	shower not working	5:00 pm	5:30 pm	Done	New shower	
13/3/24	①	D block	flush not working	9:20 Am	9:40 Am	Done	repairing	
	②	C block	Re pipe connection	11:30 Am	12:20 pm	Done	New connection	
	③	Samaya house	MIX not working	2:30 pm	4:00 pm	Done	connection	
	④	Aditya house	angle cock	4:40 pm	5:00 pm	Done	changed	
14/3/24	①	NE Hostels	Drinking water	10:00 Am	10:20 Am	Done	Solved	Ain
	②	Samaya house	connection pipe	10:40 Am	11:00 Am	Done	changed	
	③	A block	connection pipe	12:00 pm	12:20 pm	Done	changed	
	④	Aditya house	shower not working	2:40 pm	2:55 pm	Done	New shower	
	⑤	" "	flush not working	4:40 pm	5:20 pm	Done	repairing	
15/3/24	①	Aditya	brush / bow not	10:40 Am	11:00 Am	Done	New fitting	
	②	Samaya section	tap not working	12:00 pm	12:20 pm	Done	changed	
	③	Aditya 4 b	barium gun	2:15 pm	2:30 pm	Done	clear	
	④	A block	Drinking water	4:40 pm	5:00 pm	Done	clear	
16/3/24	①	C. block	Motor connection	10:30 Am	10:50 Am	Done	Solved	
	②	D block	Drinking water	11:00 pm	11:20 Am	Done	clear	
	③	Samaya 2nd floor	shower not working	1:00 pm	1:20 Am	Done	New shower	
	④	Aditya 1st floor	angle cock not w	2:30 pm	2:45 pm	Done	changed	
	⑤	Harsha House	flat not not working	4:00 pm	4:20 pm	Done	hot water clear	

Date	Sl no	Location	Complain	Start time	End time	Remarks	Job description	Sign
17/9/24	①	Aditya house	Angle cock	9:30 Am	9:40 Am	Done	Job description changed	Sign
	②	Samaya house	connection pipe	10:40 Am	10:50 Am	Done	changed	
	③	A block	tap broken	11:30 Am	12:00 Pm	Done	change	
	④	D block	flush not	4:00 Pm	4:20 Pm	Done	repairing	
	⑤	H H Ground floor	Not calling water	4:40 Pm	5:00 Pm	Done	solud	
18/9/24	①	H H 4th floor	flush not work	10:30 Am	10:50 Am	Done	repairing	
	②	Samaya house 4th floor	Angle cock	12:40 Pm	1:00 Pm	Done	change	
	③	Aditya 1st floor	Angle cock	2:30 Pm	2:50 Pm	Done	change	
	④	b block	connection pipe	4:00 Pm	4:30 Pm	Done	change	
19/9/24	①	D block	bottle tap broken	10:40 Am	11:10 Am	Done	bottle tap change	
	②	Aditya house	connection pipe	12:00 Pm	12:20 Pm	Done	change	
	③	Samaya 6th floor	Angle cock	2:00 Pm	2:20 Pm	Done	change	
	④	Samaya 3rd floor	Angle cock	4:45 Pm	5:10 Pm	Done	change	
20/9/24	①	A block	flush not working	9:20 Am	9:40 Pm	Done	repairing	Sign
	②	D block	stolen flat	10:40	10:50 Am	Done	change	
	③	Aditya house	connection pipe	2:00 Pm	2:30 Pm	Done	change	
	④	Samaya Ground floor	Hand spray not	4:00 Pm	4:30 Pm	Done	change	
	⑤	Samaya 1st floor	tap broken	4:40 Pm	5:10 Pm	Done	change	
21/9/24	①	Samaya 2nd floor	Hand spray	10:00 Am	10:30 Am	Done	New spray	
	②	D block 2nd floor	Hand spray	11:10 Am	11:40 Am	Done	New spray	
	③	A block 1st floor	Flush not working	12:10 Pm	12:40 Pm	Done	repairing	
	④	Aditya house Ground floor	shower not	4:20	4:40 Pm	Done	New shower	
22/9/24	①	H H 6th floor	Not water	9:40 Am	9:50 Am	Done	water solud	
	②	H H 5th floor	Leakage problem	12:00 Pm	12:30 Pm	Done	solud	
	③	D block	Flush not	2:30 Pm	2:00 Pm	Done	repairing	
	④	A block	connection pipe	3:10 Pm	3:30 Pm	Done	change	
	⑤	Aditya 4th floor	shower not	4:00 Pm	4:20 Pm	Done	New shower	
	⑥	Samaya Ground floor	Angle cock	4:40 Pm	5:10 Pm	Done	change	

Date	Sr.no	Location	Complain	Com time	end time	Remarks	Identification	Sign
23/3/24	(1)	Achya house	Angle cock	9:30 Am	9:50 Am	Done	change	
	(ii)	Samaya house	connection pipe	10:00 Am	10:45 Am	Done	change	
	(iii)	c block	connection pipe	3:10 pm	3:30 pm	Done	change	
	(iv)	D block	Hand spray	4:10 pm	4:30 pm	Done	change	
24/3/24	(1)	Samaya house	Angle cock	9:20 Am	9:30 Am	Done	change	
	(ii)	Samaya 3rd floor	Helioset	10:40 Am	11:10 Am	Done	New Helioset	
	(iii)	Achya 2nd floor	tap broken	2:20 Am	2:40 pm	Done	New tap	
	(iv)	H H 1st floor	vulb leakage	4:10 pm	4:50 pm	Done	Solved	
25/3/24	(1)	Samaya house	leakage problem	10:00 Am	10:40 Am	Done	Solved	
	(ii)	Achya 4th floor	leakage	12:00 pm	12:40 pm	Done	Solved	
	(iii)	A block	Angle cock	2:00 pm	2:30 pm	Done	change	
	(iv)	D block	Angle cock	4:40 pm	4:50 pm	Done	change	
26/3/24	(1)	H H 2nd floor	connection pipe	10:10 Am	10:30 Am	Done	change	
	(ii)	Samaya 1st floor	flush vat	12:00	12:40 pm	Done	repairing	
	(iii)	Achya house	vulb broken	4:40 pm	5:20 pm	Done	repairing	
27/3/24	(1)	Achya house	-tap broken	9:45 Am	10:00 Am	Done	change	
	(ii)	Samaya house	-Angle cock	10:40 Am	11:00 Am	Done	change	
	(iii)	b block	Drinking water	2:45 pm	3:00 pm	Done	Solved	
	(iv)	D block	leakage	3:10 pm	4:00 pm	Done	Solved	
28/3/24	(1)	D block	leakage	10:30 Am	11:00 Am	Done	Solved	
	(ii)	b block	-Angle cock	12:00 pm	12:20 pm	Done	changed	
	(iii)	c block	Angle cock	2:30 pm	3:00 pm	Done	changed	
	(iv)	Samaya 6th floor	connection pipe	4:00 pm	4:30 pm	Done	New pipe	
	(v)	Achya 2nd floor	Mixture broken	5:10 pm	5:30 pm	Done	repairing	
29/3/24	(1)	Samaya 7th floor	Mixerie broken	10:40 Am	12:00 pm	Done	repairing	
	(ii)	Achya house	shower mat	2:00 pm	2:30 pm	Done	New shower	
	(iii)	H H Ground floor	shower mat	4:10 pm	4:30 pm	Done	New shower	
	(iv)	Samaya 2nd floor	Angle cock	4:50 pm	5:20 pm	Done	changed	

Signature

Date	S.no	Location	Complain	Com-bance	End-time	Remarks	Identification	Eng
20/4/24	①	Achya house	Removal from	9:20 Am	9:40 Am	Done	Change	
	②	Samaya house	angle cock	12:30 Am	12:50 Am	Done	Change	
	③	A block 2nd floor	half net	2:30 Am	2:50 Am	Done	Change	
	④	b block	Drinking water	4:10 Am	4:30 Am	Done	Solved	
22/4/24	①	Samaya house 3rd floor	M2 face net	10:10 Am	11:10 Am	Done	repairing	
	②	D block	Tap Net	1:50 Am	2:10 Am	Done	Change	
	③	Achya house	connection pipe	2:40 Am	2:55 Am	Done	Change	
	④	H.H 2nd floor	Angle cock	4:20 Am	4:40 Am	Done	Change	
	⑤	Samaya house 1st floor	Drinking water	5:10 Am	5:30 Am	Done	Solved	
23/4/24	①	b block 2nd floor	connection pipe	9:30 Am	9:45 Am	Done	Change	
	②	Samaya 6th floor	Angle cock	12:00 Am	12:20 Am	Done	Change	
	③	Achya house (LD)	Flush not working	2:00 Am	2:40 Am	Done	repairing	
	④	c block	fire alarm	4:25 Am	5:00 Am	Done	clean	
24/4/24	①	Samaya house 4th floor	bottle-top jam	10:00 Am	10:25 Am	Done	clean	
	②	H.H 5th floor	Angle cock	12:10 Am	12:25 Am	Done	change	
	③	Achya house 3rd floor	Angle cock	2:30 Am	3:45 Am	Done	change	
	④	D block 2nd floor	flush hot	4:00 Am	4:45 Am	Done	repairing	
25/4/24	①	D block 1st floor	flush not working	9:45 Am	10:00 Am	Done	repairing	
	②	Samaya house 7th floor	Angle cock	12:30 Am	12:45 Am	Done	Change	
	③	H.H 5th floor	Drinking water	4:00 Am	4:15 Am	Done	Solved	
	④	Achya house 2nd floor	leakage	4:40 Am	5:10 Am	Done	Solved	
26/4/24	①	D block	leakage	9:30 Am	10:00 Am	Done	Problem Solved	
	②	Samaya house	leakage	12:00 Am	12:40 Am	Done	Problem Solved	
	③	Achya house	Flush not	1:30 Am	1:50 Am	Done	repairing	
	④	A block	half net	2:40 Am	3:00 Am	Done	Change	
	⑤	H.H 2nd floor	Angle cock	3:45 Am	4:00 Am	Done	Change	
	⑥	Achya 2nd floor	Angle cock	4:15 Am	4:40 Am	Done	Change	
	⑦	Hexamsh	connection	4:45 Am	5:00 Am	Done	Change	

Date	Sl no	Location	Complain	Com time	End time	Remarks	Identification	Eng
07/4/24	①	Aditya house	Flush not working	9:30 Am	9:45 Am	Done	Flush repairing Repairing change change Solved	Eng
	②	Samaya house	Flush not working	11:30 Am	12:00 Am	Done		
	③	B block 2nd floor	Angle cock	2:45 Pm	3:00 Pm	Done		
	④	H H 2nd floor	connection pipe	3:45 Pm	4:00 Pm	Done		
	⑤	C block top	Drinking water	4:15 Pm	4:30 Pm	Done		
08/4/24	①					Done		
						Done		
						Done		
						Done		
09/4/24	①	Samaya house	Angle cock	10:00 Am	10:10 Am	Done	change New fitting cleaning	
	②	Aditya house	NV broken	1:45 Pm	2:15 Pm	Done		
	③	H H top	back wash	2:45 Pm	3:15 Pm	Done		
10/4/24	①	Aditya 4b	-top broken	10:45 Am	11:15 Am	Done	-top change change change repairing change	Eng
	②	Samaya 2nd floor	Angle cock	11:30 Am	11:45 Am	Done		
	③	Samaya 4th floor	connection pipe	12:45 Pm	1:15 Pm	Done		
	④	H H 5th floor	Flush not working	2:45 Pm	3:15 Pm	Done		
	⑤	A block 1st floor	Angle cock	3:45 Pm	4:10 Pm	Done		
11/4/24	①	b block 2nd floor	Angle cock	9:15 Am	9:30 Am	Done	change change changed	
	②	Samaya 7th floor	Connection pipe	2:15 Pm	2:30 Pm	Done		
	③	Aditya 3D	Mixture not	3:15 Pm	4:10 Pm	Done		
12/4/24	①	Aditya 5th floor	Shower not working	9:30 Am	10:30 Am	Done	Shower changed shower changed changed repairing	
	②	Aditya 3rd floor	Shower net	10:45 Am	11:15 Am	Done		
	③	Samaya 1st floor	Angle cock	2:00 Pm	2:15 Pm	Done		
	④	b block 5th floor	Flush not	4:00 Pm	4:25 Pm	Done		
13/4/24	①	A block 1st floor	Angle cock not	10:00 Am	10:20 Am	Done	change change repairing	
	②	H H 2nd floor	Angle cock not	1:45 Pm	2:00 Pm	Done		
	③	Aditya house	Flush not working	4:15 Pm	4:45 Pm	Done		

Date	Sl no	Location	Complain	Com time	end time	Remarks	Identification	Sign
14/1/24	①	Aditya house 1st floor	Angle cock	9:25Am	9:40Am	Done	changed	
	②	B block 2nd floor	Flush not	11:45Am	12:30Am	Done	repairing	
	③	D block Ground floor	Flush not	2:45pm	3:15pm	Done	repairing	
	④	Ganmaya 1st floor	connection pipe	4:00pm	4:15pm	Done	changed	
15/1/24	①	Ganmaya 3rd floor	Angle cock	10:00Am	10:15Am	Done	changed	
	②	Aditya 4b	shower not working	11:00Am	11:30Am	Done	changed	
	③	D block 2nd floor	flush not working	2:00pm	2:30pm	Done	repairing	
	④	H.H 1st floor	Hand shower	2:45pm	3:00pm	Done	changed	
	⑤	Hexamsh 1st floor	Half set not	4:15pm	4:30pm	Done	changed	
16/1/24	①	A block 1st floor	Flush not working	10:15Am	10:45Am	Done	repairing	
	②	b block 3rd floor	connection pipe	2:30pm	2:45pm	Done	changed	
	③	Aditya house	Angle cock not	3:45pm	4:00pm	Done	changed	
	④	D block top	Drinking water not	4:15pm	4:30pm	Done	Solved	
17/1/24	①	D block 2nd floor	Flush not working	9:45Am	10:10Am	Done	repairing	AJM
	②	b block top	Drinking water	11:45Am	12:15Am	Done	Solved	
	③	Ganmaya house	Drinking water	2:00pm	2:30pm	Done	Solved	
	④	Aditya house	Angle cock	4:00pm	4:15pm	Done	changed	
	⑤	Aditya 1st floor	Angle cock	4:30pm	4:45pm	Done	changed	
18/1/24	①	A block 2nd floor	connection pipe	10:05Am	10:25Am	Done	changed	
	②	b block 1st floor	Angle cock	2:05pm	2:20pm	Done	changed	
	③	C block top	Drinking water	4:00pm	4:00pm	Done	Solved	
19/1/24	①	Hexamsh House	tap not working	9:40Am	10:10Am	Done	changed	
	②	A block 3rd floor	Drinking water	12:00pm	12:45pm	Done	Solved	
	③	b block 2nd floor	Flush not working	3:30pm	4:00pm	Done	repairing	
20/1/24	①	A block 4th floor						
	②	Ganmaya 3rd floor						
	③	Aditya house						

Date	S/NO	Location	Complain	Com-time	End-time	Remarks	Identification	Sign
21/4/24	①	D block Ground floor	Angle cock	9:20Am	9:30Am	Done	changed	
	②	A block 4th floor	Connection pipe	10:10Am	10:25Am	Done	changed	
	③	Samaya house	Angle cock	11:45Am	12:00Pm	Done	changed	
	④	Aditya 4b	Mixture not	2:00Pm	2:40Pm	Done	changed	
22/4/24	①	B block 4th floor	connection pipe	10:00Am	10:20Am	Done	changed	
	②	D block 6th floor	Helto set not	10:45Am	11:15Am	Done	repairing	
	③	H H House 1st	Angle cock	12:00Pm	12:20Pm	Done	changed	
	④	Heyamsh 2nd floor	tap not	2:20Pm	2:40Pm	Done	repairing	
	⑤	Samaya 1st floor	connection pipe	4:00Pm	4:20Pm	Done	changed	
23/4/24	①	Samaya 7th floor	Mixture not	9:00Am	10:45Am	Done	repairing	
	②	A block 5th floor	Angle cock	12:15Pm	12:30Pm	Done	changed	
	③	H H 4th floor	Angle cock	2:15Pm	2:30Pm	Done	changed	
	④	Aditya 6th floor	Helto set not	3:45Pm	4:00Pm	Done	changed	
24/4/24	①	Aditya house 5th floor	Flush not working	10:00Am	10:30Am	Done	repairing	Ajay
	②	Samaya 4th floor	Flush not	11:20Am	11:45Am	Done	repairing	
	③	A block Ground floor	tap not	2:10Pm	2:40Pm	Done	changed	
	④	D block 4th floor	Flush not	4:30Pm	4:50Pm	Done	repairing	
25/4/24	①	D block 6th floor	Helto set not	10:00Am	10:30Am	Done	changed	
	②	Samaya 2nd floor	Angle cock	12:45Pm	1:15Pm	Done	changed	
	③	Aditya house 6th floor	Mixture not	2:22Pm	3:00Pm	Done	changed	
	④	C block 2nd floor	Dr leakage	4:00Pm	4:45Pm	Done	Solved	
26/5/24	①	A block 2nd floor	leakage	10:00Am	10:45Am	Done	Solved	
	②	Aditya 3D	leakage	12:00	12:45Pm	Done	Solved	
	③	Samamaya 2nd floor	Angle cock	2:10Pm	2:20Pm	Done	changed	
	④	Samaya 6th floor	Flush not	2:45Pm	3:00Pm	Done	repairing	
	⑤	D block 1st floor	Flush not	4:00Pm	4:20Pm	Done	repairing	
	⑥	D block 2nd floor	Helto set not	4:30Pm	5:00Pm	Done	changed	